

329-2014 ADDENDUM 4

NORTH KILDONAN FEEDERMAIN REPLACEMENT

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: May 13, 2014
BY: Colin McKinnon
TELEPHONE NO. (204) 942-6391

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20131129

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: E22.5 Title to read:

Flanged / Compression Sleeve Coupling – F/C Coupling

Add: E22.10 Dismantling Joint

- (a) Flange Spool: AWWA Class D Ring Flange, compatible with ANSI Class 125 and 150 bolt circles. For 3" - 12" sizes, pipe is Sch 40 ASTM A53. For 14" - 72" sizes, ASTM A36 Carbon Steel.
- (b) End Ring & Body: For 3" - 12" sizes, body and end ring are ASTM A536 ductile (nodular) iron meeting or exceeding Grade 65-45-12. For 14" - 72" ASTM A36 Carbon Steel with AWWA C207 Class D flanges. 3" - 72" meet the dimensional requirements of ANSI Class 125 and 150 bolt circles.
- (c) Gaskets: Compounded for water and sewer service in accordance with ASTM D 2000 (ductile iron flange bodies, 3" - 12" have flange o-ring gaskets).
- (d) Bolts & Nuts: High strength low alloy steel bolts and nuts. Steel meets ASTM A588.
- (e) Coating : Fusion bonded epoxy, NFS 61 certified.
- (f) Tie-Rods : High strength steel per ASTM A193 B7.