



- GENERAL NOTES**
1. ALL CONCRETE TO HAVE 28 DAY COMPRESSIVE STRENGTH OF 3000 P.S.I.
  2. ALL REINFORCEMENT BARS TO BE EPOXY COATED BARS OF INTERMEDIATE GRADE, UNLESS NOTED OTHERWISE.
  3. MAX. SIZE AGGREGATE TO BE 1/4" IN SLABS AND WALLS AND 3/4" IN BEAMS AND PILES.
  4. MIN. CONCRETE PROTECTION FOR REINFORCEMENT TO BE IN ACCORDANCE WITH AC 308. ALL SLABS TO BE REINFORCED WITH #3 STIRRUPS AT 18" ON CENTER.
  5. UNLESS OTHERWISE DETAILLED, PROVIDE CHECKER AROUND OPENINGS.
  6. TOP STEEL IN BEAMS LAPPED AT MID-SPAN. BOTTOM STEEL LAPPED AT SUPPORTS.
  7. FOR SIZE OF BEAMS, LOCATION OF BEAMS, WALLS AND ARCHES, SEE MECHANICAL DRAWINGS.
  8. PROVIDE 5/8" DIA. STUD BOLTS AND WELD WELLS BEARING CONNECTION WALLS.

NO.	REVISIONS	DATE	BY	CHKD.
B-14				

**FILE**

RETURN TO CIVIC PROPERTIES INCLUDING INVENTORY.

3 02 4

**PROVIDER OF MATERIAL REGISTERED ENGINEER**

A.F. ESHMADE

APPROVED BY: *[Signature]* DATE: 10/2/67

**TRANSCONA SWIMMING POOL BUILDING**

STRUCTURAL FLOOR PLAN & DETAILS

DWIGHT R. JOHNSTON M.R.A.I.C.  
ARCHITECT

1854 PORTAGE AVE. ST. JAMES MANITOBA

**UNDERWOOD McLELLAN & ASSOCIATES**  
LIMITED

CONSULTING PROFESSIONAL ENGINEERS

MANITOBA SASKATCHEWAN ALBERTA BRITISH COLUMBIA

DRAWN BY: *[Signature]* DESIGNED BY: R.F.C.

CHECKED BY: *[Signature]* SCALE: AS SHOWN

DATE DRAWN: 31st MARCH 1967

JOB NO: 23-723-02 DRAWING NO:

SHEET 10 OF 16

**S.2A**