


## FIRST FLOOR PROCESS PLAN

**DILLON**CONSULTING



1/2 June 13/14 MOORE CONSULTANT DRAWING NO. WM-E0112

## THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT Winnipeg ENGINEERING DIVISION

WATER TREATMENT PLANT GENERAL PLANT SERVICES/MISCELLANEOUS MECHANICAL AND ELECTRICAL

SCALE 1:100

SCALE 1:1

NOTES:

REQUIREMENT.

1. SEE CONSULTANT DRAWING No. WB—E0512 MCC #1A & #1B SINGLE LINE DIAGRAM FOR 600V POWER DISTRIBUTION.

3. PROVIDE TRANSFORMER GROUNDING TO THE REQUIREMENT OF MANITOBA HYDRO. REFER TO DETAIL WB-E0456 FOR MINIMUM

4. SEE CBD-M-4 FOR MISCELLANEOUS COMMUNICATION NET WORK WIRING BETWEEN SWITCHGEAR, MCC'S, AND LCP'S.

2. ALL 120V AND 208V LOADS ARE FED FROM LP-M11.

**ELECTRICAL** ELECTRICAL ROOM AREA FIRST FLOOR PROCESS PLAN CITY FILE NUMBER SHEET CITY DRAWING NUMBER 1-0601M-E0019-001-05

KEY PLAN