


G-X330
OZONE GENERATOR
CAPACITY: 0.29 Kg/d

GD-X331
OZONE DESTRUCT UNIT
CAPACITY: 28 Nm³/h
POWER: 0.6 kW

AHU-X332
AIR PREPARATION UNIT
CAPACITY: 4.86 m³/hr

DEM-X333
DEMISTER



NOTES:

* CITY OF WINNIPEG TO SUPPLY EQUIPMENT/ INSTRUMENTATION. CONTRACTOR TO INSTALL.



B.M. ELEV.			
CONSTRUCTION COMPLETION DATE: YYYY MM DD			
DESIGNED BY	KG	CHECKED BY	BW
DRAWN BY	JBC	APPROVED BY	BW
SCALE:	NTS	RELEASED FOR CONSTRUCTION	
HORIZONTAL			
VERTICAL			
0 ISSUED FOR TENDER	14/06/13	JBC	
NO.	REVISIONS	DATE	BY
		2014 06 13	

CH2MHILL

DESIGNED BY: KG, CHECKED BY: BW
 DRAWN BY: JBC, APPROVED BY: BW
 SCALE: HORIZONTAL: NTS, VERTICAL: -
 DATE: 2014 06 13, PLOT DATE: 2014 06 13

ENGINEER'S SEAL

CONSULTANT DRAWING NUMBER: WX-P0010

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT
ENGINEERING DIVISION

CITY OF WINNIPEG WATER TREATMENT RESEARCH AND PROCESS OPTIMIZATION FACILITY
PROCESS OZONE GENERATION AND DESTRUCT SYSTEMS PROCESS AND INSTRUMENTATION DIAGRAM

SHEET X OF X
CITY DRAWING NUMBER: 1-0601X-P0007-001-00