



744-2014 ADDENDUM 1

SUPPLY AND DELIVERY OF COLD MIX ASPHALT

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: August 11, 2014
BY: Jean-Luc Lambert, E.I.T.
TELEPHONE NO. (204) 806-0786

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20131129

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: E4.1.3 to read: The limestone retained on the No. 5000 sieve shall contain not less than one hundred (100%) percent crushed aggregate as determined by actual particle count. Crushed aggregate shall be considered as that aggregate having at least two freshly fractured faces.