


1 VOLTAGE MONITOR SCHEMATIC  
SCALE: N.T.S

NOTES:

- POWER MONITOR SETPOINTS AS FOLLOWS:  
UNBALANCE: 9%  
LINE VOLTAGE: 600V  
TRIP DELAY: 2 SEC  
RESTART DELAY: 10 SEC  
SELECTOR: AUTO RESTART WITH DELAY
- CONTACT IS CLOSED DURING NORMAL OPERATION AND IS OPEN DURING A FAULT OR LOSS OF POWER.

File Name: P:\Projects\2013\13-0107-026\Elec\13-0107-026-A-E10.dwg - Tab: A-E10 Plotted By: dderoche 08/19/2014 [Tue 8:56am]



NO.	REVISIONS	DATE	BY
0	ISSUED FOR CONSTRUCTION	14/08/18	AP

DESIGNED BY	CHECKED BY
DDW/MAM	[Signature]
DRAWN BY	APPROVED BY
GCN	[Signature]
HDR. SCALE	RELEASED FOR CONSTRUCTION
N.T.S.	
VERTICAL	DATE
N.T.S.	2014 05 22

ENGINEER'S SEAL

A-E10

**THE CITY OF WINNIPEG**  
WATER AND WASTE DEPARTMENT

FLOOD PUMPING STATION UPGRADES  
ASSINIBOINE STATION  
**ELECTRICAL**  
DETAILS

SHEET 1 OF 1  
CITY DRAWING NUMBER  
1-0115F-E0007-001