



ROOF PLAN - POWER & SYSTEMS
SCALE: 1/8"=1'-0"

ELECTRICAL NOTES:

1. INSTALL DUCT SMOKE DETECTOR AS PER CANULC S224 FIGURE 24. PROVIDE DRY CONTACTS WITHIN THE FIRE ALARM CONTROL PANEL TO INTERLOCK AHU-2 WITH DUCT SMOKE DETECTOR FOR SHUT DOWN.
2. COORDINATE EXACT LOCATION OF MECHANICAL EQUIPMENT WITH MECHANICAL DRAWINGS.

NOTES:

THESE DRAWINGS SHALL NOT BE SCALED.
THE CONTRACTOR SHALL VISIT THE SITE AND SATISFY ONESELF ALL DIMENSIONS, DATUM, AND DETAILED INFORMATION SHOWN ARE CORRECT.
THE CONTRACTOR IS TO REVIEW AND COORDINATE ALL ARCHITECTURAL, MECHANICAL, ELECTRICAL AND STRUCTURAL DRAWINGS FOR ADDITIONAL OPENINGS THROUGH FLOORS, WALLS, AND CEILINGS FOR DUCT, PIPE & ELECTRICAL RISERS AND ALL OPENINGS NOT SHOWN ON DRAWINGS.
ALL OPENINGS THROUGH FIRE ASSEMBLIES ARE TO BE FIRE STOPPED AND SEALED WITH ULC APPROVED FIRE STOPPING TO MAINTAIN THE INTEGRITY OF THE FIRE SEPARATION, AND PROVIDE A SMOKE-TIGHT BARRIER.
ALL PRODUCTS AND MATERIALS TO BE USED AND INSTALLED SHALL CONFORM WITH MANUFACTURER'S SPECIFICATIONS & APPLICABLE CODES.
THE CONTRACTOR SHALL BE RESPONSIBLE TO PATCH AND MAKE GOOD ALL EXISTING CONSTRUCTION AFFECTED BY THE REMOVAL OF ALL ITEMS FORMING THE PART OF THE RENOVATION WORK.
WHERE NEW FLOORING AND BASE IS TO BE INSTALLED IN EXISTING AREAS (REFER TO FLOOR PLAN AND ROOM SCHEDULE) THE EXISTING FLOORING SURFACE AND BASE MUST BE REMOVED, UNLESS OTHERWISE NOTED. ALL FLOOR SURFACES SHALL BE PREPARED IN ACCORDANCE TO MANUFACTURER'S RECOMMENDATIONS FOR INSTALLATION OF NEW FLOOR.
WHERE PAINTING OF EXISTING WALLS IS INDICATED ON THE ROOM SCHEDULE, THESE WALLS MUST BE CLEANED OF ANY EXISTING WALL COVERING, PATCHED & PREPARED TO ACCEPT NEW MATERIAL, UNLESS OTHERWISE NOTED.

GENERAL CONSTRUCTION NOTES:

1. ALL NEW WIRING SHALL BE RUN IN NEW CONDUIT.
2. ALL PENETRATIONS THROUGH FIRE SEPARATIONS SHALL BE FIRE STOPPED. FOR ALL FIRE STOPPING, CONTRACTOR SHALL ENSURE THE WALL RATING IS MAINTAINED.
3. VERIFY LOAD ON EXISTING CIRCUITS PRIOR TO CONNECTION OF NEW LOADS.

LEGEND:

- PANELBOARD
- MOTOR LOAD
- EQUIPMENT
- FIRE ALARM PULL STATION
4X = NEMA 4X ENCLOSURE
- FIRE ALARM HORN/STROBE
- DENOTES:
CM = CEILING MOUNT
4X = NEMA 4X ENCLOSURE
- DENOTES NUMBER OF CANDELA FOR STROBE
- FIRE ALARM HORN/STROBE
- DUCT MOUNT SMOKE DETECTOR
- SMOKE DETECTOR
- 1520A, WEATHERPROOF, GFI RECEPTACLE - MOUNT 30" AFF
1520, WP, GFI, 30"(750mm) AFF
- WEATHERPROOF DISCONNECT SWITCH
WP

0	ISSUED FOR CONSTRUCTION	CLS	15.02.17
No.	REVISION/DESCRIPTION	BY	DATE

SEAL



DRAWN	GON	CHECKED	DESIGNED	CLS	APPROVED
DATE	2014.10.30	USER	APPROVAL		

THE CITY OF WINNIPEG
PLANNING, PROPERTY AND
DEVELOPMENT DEPARTMENT
MUNICIPAL ACCOMMODATIONS DIVISION
3-65 GARRY STREET, R3C 4K4

PROJECT
SHERBROOK POOL
REFURBISHMENT OF SHERBROOK POOL

381 SHERBROOK STREET
SHEET TITLE

ELECTRICAL
ROOF PLAN
POWER & SYSTEMS

SCALE	PROJECT No:	SHEET No:
AS SHOWN	2013-173	E12

