

Part 1 General

1.1 RELATED REQUIREMENTS

- .1 Section 03 30 00 - Cast-in-Place Concrete

1.2 REFERENCES

- .1 ASTM International
 - .1 ASTM A496/A496M-07, Standard Specification for Steel Wire, Deformed, for Concrete Reinforcement.
- .2 CSA International
 - .1 CAN/CSA-A82-06, Fired Masonry Brick Made From Clay or Shale.
 - .2 CAN/CSA-A165 SERIES-04(R2009), CSA Standards on Concrete Masonry Units covers: A165.1, A165.2, A165.3.
 - .3 CAN/CSA-A179-04(R2009), Mortar and Grout for Unit Masonry.
 - .4 CAN/CSA-A370-04(R2009), Connectors for Masonry.
 - .5 CAN/CSA A371-04(R2009), Masonry Construction for Buildings.
 - .6 CSA G30.18-09, Carbon Steel Bars for Concrete Reinforcement.
- .3 Health Canada / Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for masonry products and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Shop Drawings:
 - .1 Shop drawings consist of bar bending details, lists and placing drawings.
 - .2 Placing drawings, indicate sizes, spacing, location and quantities of reinforcement and connectors.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Store materials indoors, in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.

- .2 Store and protect masonry products from nicks, scratches, and blemishes.
- .3 Replace defective or damaged materials with new.

Part 2 Products

2.1 MASONRY UNITS

- .1 Standard concrete block units: to CAN/CSA-A165 Series (CAN/CSA-A165.1).
 - .1 Classification: H/15/A/M.
 - .2 Size: modular.
 - .3 Special shapes: provide bull-nosed units for exposed corners. Provide purpose-made shapes for lintels and bond beams. Provide additional special shapes as indicated.
- .2 Special fire resistant concrete block units: to CAN/CSA-A165 Series (CAN/CSA-A165.1) as modified below.
 - .1 Classification: H/15/B/M except as modified by fire resistance requirements specified below.
 - .2 Fire resistant characteristics: aggregate used in units and equivalent thickness of units to National Building Code of Canada 2010, for fire-resistance ratings indicated.
 - .3 Size: modular.
 - .4 Special shapes: provide bull-nosed units for exposed corners. Provide purpose-made shapes for lintels and bond beams.

2.2 REINFORCEMENT AND CONNECTORS

- .1 Bar reinforcement: to CAN/CSA-A371, Grade 400.
- .2 Wire reinforcement: to CAN/CSA-A371.
- .3 Connectors shall be corrosion resistant: to CAN/CSA-A370.

2.3 MORTAR AND GROUT

- .1 Mortar: to CAN/CSA-A179.
 - .1 Use aggregate passing 1.18 mm sieve where 6 mm thick joints are indicated.
 - .2 Colour: ground coloured natural aggregates or metallic oxide pigments.
- .2 Mortar Type: S based on property specifications,
- .3 Following applies regardless of mortar types and uses specified above:
 - .1 Mortar for stonework: type N based on property specifications.
 - .2 Mortar for grouted reinforced masonry: type S based on [property] specifications.
- .4 Grout: to CAN/CSA-A179, Table 3.

- .5 Parging mortar: type N to CAN/CSA-A179.

2.4 ACCESSORIES

- .1 Nailing Inserts: 0.5 mm minimum thickness, galvanized.
- .2 Bolts: 12 mm diameter x 150 mm long with ends bent 50 mm at 90 degrees.

Part 3 Execution

3.1 INSTALLATION

- .1 Do masonry work in accordance with CAN/CSA-A371 except where specified otherwise.
 - .1 Bond: running stretcher bond with vertical joints in perpendicular alignment and centred on adjacent stretchers above and below.
 - .2 Coursing height: 200 mm for one block and one joint.
 - .3 Jointing: tool where exposed or where paint or other finish coating is specified to provide smooth compressed concave surface.
- .2 Build masonry plumb, level, and true to line, with vertical joints in alignment.
- .3 Layout coursing and bond to achieve correct coursing heights, and continuity of bond above and below openings, with minimum of cutting.

3.2 CONSTRUCTION

- .1 Exposed masonry:
 - .1 Remove chipped, cracked, and otherwise damaged units, in exposed masonry and replace with undamaged units.
 - .2 Cut out for electrical switches, outlet boxes, and other recessed or built-in objects. Make cuts straight, clean, and free from uneven edges.
- .2 Building-in:
 - .1 Install masonry connectors and reinforcement where indicated on drawings.
 - .2 Build in items required to be built into masonry.
 - .3 Prevent displacement of built-in items during construction. Check plumb, location and alignment frequently, as work progresses.
 - .4 Brace door jambs to maintain plumb. Fill spaces between jambs and masonry with mortar.
 - .5 Install loose steel lintels over openings where indicated.
- .3 Concrete block lintels:
 - .1 Install reinforced concrete block lintels over openings in masonry where steel or reinforced concrete lintels are not indicated.
 - .2 End bearing: not less than 200 mm.
- .4 Support of loads:

- .1 Use 32] MPa concrete to Section 03 30 00 - Cast-in-Place Concrete, where concrete fill is used in lieu of solid units.
- .2 Use grout to CAN/CSA-A179 where grout is used in lieu of solid units.
- .3 Install building paper below voids to be filled with concrete or grout; keep paper 25 mm back from faces of units.
- .5 Interface with other work:
 - .1 Cut openings in existing work as indicated.
 - .2 Openings in walls: approved by Contract Administrator.
 - .3 Make good existing work. Use materials to match existing.

3.3 REINFORCING AND CONNECTING

- .1 Install masonry connectors and reinforcement in accordance with CAN/CSA-A370, CAN/CSA-A371 and CSA S304.1 unless indicated otherwise.
- .2 Prior to placing concrete, mortar or grout, obtain Contract Administrator's approval of placement of reinforcement and connectors.

3.4 REINFORCED LINTELS AND BOND BEAMS

- .1 Reinforce masonry lintels and bond beams as indicated.
- .2 Place and grout reinforcement in accordance with CAN/CSA-A179, CAN/CSA-A371 and CSA S304.1.

3.5 GROUTING

- .1 Grout masonry in accordance with CAN/CSA-A179, CAN/CSA-A371 and CSA S304.1 and as indicated.

3.6 ANCHORS

- .1 Supply and install metal anchors as indicated.

3.7 LATERAL SUPPORT AND ANCHORAGE

- .1 Supply and install lateral support and anchorage in accordance with CSA S304.1 and as indicated.

3.8 SITE TOLERANCES

- .1 Tolerances of CAN/CSA-A371 apply.

3.9 FIELD QUALITY CONTROL

- .1 Inspection and testing will be carried out by Testing Laboratory designated by Contract Administrator.

3.10 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Leave Work area clean at end of each day.

- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.

3.11 PROTECTION

- .1 Protect masonry and other work from marking and other damage. Protect completed work from mortar droppings. Use non-staining coverings.
- .2 Repair damage to adjacent materials caused by masonry products installation.

END OF SECTION