



DIMENSIONS SHOWN ARE TO THE EXTERIOR FACE OF CONCRETE WALL (TYPICAL)

GENERAL NOTES HHW BUILDING

GENERAL NOTES

- REFER TO DRAWING S1 FOR STANDARD DETAILS AND ADDITIONAL GENERAL NOTES.
- GEOTECHNICAL ENGINEER TO INSPECT THE GRADE PRIOR TO PLACING GRANULAR.
- USE A BACKHOE WITH A SMOOTH BUCKET FROM THE EDGE OF THE EXCAVATION TO MINIMIZE DISTURBANCE OF THE SUBGRADE.
- PROTECT SUBGRADE FROM FREEZING, DRYING OR INSULATE WITH MATS.
- SCARIFY EXPOSED SUBGRADE TO A DEPTH OF 300mm, ADJUST MOISTURE CONDITIONS AND RECOMPACT TO 95% SPMDD.
- PROOF ROLL SUBGRADE WITH FULLY LOADED TANDEM AXLE TRUCK TO DETECT WEAK OR SOFT AREAS IN THE PRESENCE OF THE GEOTECHNICAL ENGINEER.
- REPAIR WEAK OR SOFT AREAS BY EXCAVATING A MINIMUM OF 300mm, PLACING A GEOTEXTILE LAYER AND BACKFILL WITH 19mm DOWN CRUSHED LIMESTONE (WELL GRADED) COMPACTED TO 100% SPMDD (LIFT THICKNESS NOT TO EXCEEDING 150mm)
- ALL SLAB ON GRADE FLOORS WILL EXPERIENCE MOVEMENT AND CRACKING DUE TO HEAVING AND SOIL EXPANSION RESULTING FROM THE NATURE OF THE CLAY SOIL. PREVIOUS AND PRESENT LEVEL OF VEGETATION AT THE SITE, SOIL MOISTURE LEVEL AND CONSTRUCTION PRACTICES. DILLON CONSULTING LIMITED ACCEPTS NO LIABILITY FOR THIS CRACKING AND / OR MOVEMENT.

DESIGN DATA

- CLIMATIC DATA: WINNIPEG, MANITOBA
- LOADING CRITERIA (NORMAL IMPORTANCE):
 SNOW: $S_s = 1.9$ kPa, $S_r = 0.2$ kPa
 $I_s = 1.0$ (ULS), 0.9 (SLS)
 WIND: $Q_{50} = 0.45$ kPa
 $I_w = 1.0$ (ULS), 0.75 (SLS)
 SEISMIC: NOT APPLICABLE

DESIGN LOAD

- LIVE LOAD ON FLOOR SLAB= 14.4 kPa + 1.0 kPa PARTITION ALLOWANCE.
- ATTIC LOAD = 0.5 kPa

CONCRETE REINFORCING

- PERFORM REINFORCING WORK IN ACCORDANCE WITH CSA 23.1-14.
- REINFORCING STEEL SHALL CONFORM TO CAN/CSA G30.18-09, GRADE 400R OR 400W.

STRUCTURAL STEEL

- PERFORM STRUCTURAL STEEL WORK IN ACCORDANCE WITH CAN/CSA-S16-14.
- ALL FABRICATION AND WELDING SHALL CONFORM TO CSA W59-03 AND BE PERFORMED BY A COMPANY CERTIFIED BY AND WELDERS QUALIFIED IN ACCORDANCE WITH CSA W47.1-03 (R2008) FOR DIVISION 1 OR DIVISION 2.1.
- FILLET WELDS SHALL NOT BE LESS THAN 5 mm.
- WELDING ELECTRODES TO BE "BASIC" LOW HYDROGEN TYPE, TO CSA W48 SERIES, COMPATIBLE WITH STEEL TO BE WELDED.
- STRUCTURAL SHAPES TO CSA G40.21-04, GRADE 350W.
- STRUCTURAL PLATES TO CSA G40.21-04, GRADE 300W (MINIMUM).
- HOLLOW STRUCTURAL SECTIONS TO CAN/CSA G40.21-04 (R2009), GRADE 350W, CLASS C.
- HIGH TENSILE BOLTS, NUTS AND WASHERS TO ASTM A325-09.
- ANCHOR BOLTS AND NUTS TO ASTM A36/A36M-12.
- ALL STRUCTURAL STEEL TO BE GALVANIZED.
- IF FIELD WELDING OF GALVANIZED MEMBERS IS REQUIRED, GRIND OFF GALVANIZING IN WELD AREA. TOUCH UP AREA AFTER WELDING WITH 2 COATS OF ZINC CLAD IV BY SHERWIN-WILLIAMS OR CONSULTANT APPROVED EQUAL.

PLAN - ELEVATION 231.90
1:50

METRIC

WHOLE NUMBERS INDICATE MILLIMETRES
DECIMALIZED NUMBERS INDICATE METRES



B.M. ELEV.	DESIGNED BY	WH
	DRAWN BY	PDR
	CHECKED BY	NR
	APPROVED BY	ARR
	HOR. SCALE	AS NOTED
	VERTICAL	
1	ISSUED FOR TENDER	16/03/04 ARR
NO.	REVISIONS	DATE BY DATE

DILLON CONSULTING

RELEASED FOR CONSTRUCTION

DATE

ENGINEER'S SEAL

PROVINCE OF MANITOBA

Member 23609

CONSULTANT PROJECT NUMBER

13-8224

THE CITY OF WINNIPEG
PUBLIC WORKS DEPARTMENT

4R WINNIPEG DEPOT
PACIFIC AVENUE

HHW EWASTE BUILDING PLAN
@ EL. 231.90, GENERAL NOTES

CITY DRAWING NUMBER
1-0851A-S0007-001

SHEET 15 OF 43

CONSULTANT DRAWING NUMBER
S-7