

Part 1 General

1.1 SECTION INCLUDES

- .1 Fireproof firestopping and fire-safing materials and accessories.

1.2 RELATED SECTIONS

- .1 Section 06 10 13 - Wood Blocking and Curbing.
- .2 Section 09 21 16 - Gypsum Board Assemblies.
- .3 Structural Specifications.
- .4 Mechanical Divisions – Heating, Ventilating, and Air-Conditioning (HVAC):
Mechanical work requiring firestopping.
- .5 Electrical Divisions: Electrical work requiring firestopping.

1.3 REFERENCES

- .1 ASTM E84-09c - Test Method for Surface Burning Characteristics of Building Materials.
- .2 ASTM E119-09c - Method for Fire Tests of Building Construction and Materials.
- .3 ASTM E814-09 - Test Method of Fire Tests of Through-Penetration Fire Stops.
- .4 ASTM E1966-07 - Test Method for Fire-Resistive Joint Systems.
- .5 CAN/ULC-S101-07 - Fire Endurance Tests of Building Construction and Materials.
- .6 CAN/ULC-S102-07 - Method of Test for Surface Burning Characteristics of Building
Materials and Assemblies.
- .7 CAN/ULC-S115-05 - Fire Tests of Firestop Systems.
- .8 FM (Factory Mutual) - FM 4991, Approval of Firestop Contractors.
- .9 FCIA (Firestop Contractors International Association) - Manual of Practice.
- .10 NFPA 251 - Fire Tests of Building Construction and Materials.
- .11 OPL (Omega Point Laboratories).
- .12 UL 263 - Fire Tests of Building Construction and Materials (ASTM E119, NFPA 251).
- .13 UL 1479 - Fire Tests of Through-Penetration Firestops. (ASTM E814).
- .14 UL 1709 - Rapid Rise Fire Tests of Protection Materials for Structural Steel.
- .15 UL 2079 - Tests for Fire Resistance of Building Joint Systems.

- .16 ULC (Underwriters Laboratories of Canada) - List of Equipment and Materials for:
 - .1 Building Materials.
 - .2 Fire Resistance.
 - .3 Firestop Systems and Components.
- .17 WHI (Intertek/Warnock Hershey).
- .18 Standard Method of Fire Tests Through Penetration Fire Stops, ULC-S115-M.2005/
CAN4- S115-M.2005 or ASTM E814 Test Requirements.
- .19 Underwriters Laboratories of Canada (ULC) CAN4-S115-M.2005 under their
designation of ULC-S115-M.2005 and publishes the results in FIRE RESISTANCE
RATINGS DIRECTORY.

1.4 DEFINITIONS

- .1 Firestopping (Fire-safing): A sealing or stuffing material or assembly placed in spaces
between building materials to arrest the movement of smoke, heat, gases, or fire through
wall or floor openings.

1.5 SYSTEM DESCRIPTION

- .1 Firestopping systems installed to resist spread of fire and passage of smoke and other
gases at penetrations through fire resistance rated wall, and floor assemblies, materials
and components.

1.6 PERFORMANCE REQUIREMENTS

- .1 Materials, accessories and application procedures listed by ULC, cUL, or tested to
CAN/ULC-S115 to comply with building code requirements.
- .2 Firestopping Materials: CAN/ULC-S101, ASTM E119, ASTM E814 to achieve a fire
rating as noted on Drawings.

1.7 ADMINISTRATIVE REQUIREMENTS

- .1 Coordination: Coordinate with other work having a direct bearing on work of this
section.

1.8 SUBMITTALS FOR REVIEW

- .1 Section 01 33 00: Submittal Procedures.
- .2 Product Data: Provide data on product characteristics, performance and limitation
criteria.
- .3 System Design Listings: Submit system design listings, including illustrations from a
qualified testing and inspection agency that is applicable for each firestop configuration.

1.9 SUBMITTALS FOR INFORMATION

- .1 Section 01 33 00: Submittal procedures.

- .2 Installation Data: Manufacturer's special preparation and installation requirements.
- .3 Manufacturer's Certificate: Certify that Products meet or exceed specified requirements.

1.10 CLOSEOUT SUBMITTALS

- .1 Section 01 78 00: Closeout Submittal.

1.11 QUALITY ASSURANCE

- .1 Contractor Qualifications: Company specializing in performing the work of this section and as follows:
 - .1 FM approved in accordance with FM standard 4991 - Approval of Firestop Contractors.
 - .2 FCIA Member in good standing.
 - .3 Licensed by the province or local authority where applicable.
 - .4 Successfully completed not less than five (5) comparable scale projects.
- .2 Single Source Responsibility: Obtain firestop systems for each type of penetration and construction situation from a single primary firestop systems manufacturer.

1.12 REGULATORY REQUIREMENTS

- .1 Conform to applicable code for fire resistance ratings and surface burning characteristics.
- .2 Provide certificate of compliance from authority having jurisdiction indicating approval of materials used.

1.13 DELIVERY, STORAGE, AND PROTECTION

- .1 Section 01 61 00: Transport, handle, store, and protect products.
- .2 Deliver firestopping products in original, unopened containers with labels intact and legible, identifying product and manufacturer.
- .3 Store and handle firestopping materials to manufacturer's instructions.

1.14 ENVIRONMENTAL REQUIREMENTS

- .1 Sequence work to permit installation of firestopping and smoke seal materials to be installed after adjacent work is complete and before closure of spaces.
- .2 Do not install firestopping when ambient or substrate temperatures are outside limits permitted by manufacturers or when substrates are wet, due to rain, frost, condensation, or other causes.
- .3 Maintain this minimum temperature before, during and for three (3) days after installation of materials.
- .4 Ventilate firestopping per manufacturers' instructions by natural means or, where this is inadequate, forced air circulation.

- .5 During installation, provide masking and drop sheets to prevent firestopping materials from contaminating any adjacent surfaces.
- .6 Do not use materials that contain flammable solvents.
- .7 Water based products are unacceptable in wet areas or areas that may be subject to occasional flooding.

1.15 WARRANTY

- .1 Manufacturers shall warrant work of this Section against defects and deficiencies in the product material for a period of two (2) years from date of Substantial Performance, in accordance with General Conditions of Contract. Promptly correct any defects or deficiencies, which become apparent within warranty period at no expense to City of Winnipeg.
- .2 Fire and smoke stop system Contractor hereby warrants workmanship on material installation for period of two (2) years from date of Substantial Performance, in accordance with General Conditions of Contract. Promptly correct any defects or deficiencies, which become apparent within warranty period at no expense to City of Winnipeg.

Part 2 Products

2.1 MATERIALS

- .1 System 1:
 - .1 Firestopping at joints of floor to wall construction, filling gaps and holes in fire rated assemblies, and filling voids around service penetrations through fire rated assemblies. Install damming material where support for sealant is required.
 - .2 Materials:
 - .1 Mineral wool backing insulation: ULC labelled, preformed non combustible or intumescent composite sheet.
 - .1 Standard of Acceptance:
 - .1 3M Brand Fire Barrier CS 195 Composite Sheet.
 - .2 A/D Fire Barrier mineral wool by A/D Fire Protection.
 - .2 Fire stopping sealant: ULC labelled, single component silicone based or intumescent sealant.
 - .1 Standard of Acceptance:
 - .1 3M Brand Fire Barrier Mouldable putty or CP25WB, CP 25N/S or CP 25 S/L caulk
 - .2 A/D Silicone Firebarrier by A/D Fire Protection.
 - .3 Fire Stop Sealant by Dow Corning Canada Inc.
 - .4 Tremco FYRE SIL
 - .5 Firetemp by Johns Mansville.
 - .2 System 2:

- .1 Firestopping for filling voids around multiple service penetrations through fire rated assemblies. Install damming material to temporarily contain firestopping foam.
- .2 Materials:
 - .1 Firestopping foam: ULC labelled two component silicone foam, foam mortar or intumescent firestopping.
 - .1 Standard of Acceptance:
 - .1 3M Brand Fire Barrier FS 195 Wrap/Strip, 7904 Series system or CS 195 Composite sheet with CP 25 S/L elastomer or mouldable putty.
 - .2 A/D firebarrier mortar or A/D Silicone over A/D firebarrier Mineral Wool Firestopping.
 - .3 Dow Corning 3 6548 Silicone RTV Foam or Dow Corning Fire Stop Intumescent Wrap Strip over damming material.
- .3 System 3:
 - .1 Firestopping PVC, CPVC and ABS plastic pipe penetration through fire rated assemblies.
 - .2 Materials:
 - .1 Intumescent UL classified as a through penetration firestop device when tested in accordance with ASTM E814 (UL 1479). Complete with retainer clip.
 - .1 Standard of Acceptance:
 - .1 3M Firebarrier Plastic Pipe Device utilizing FS 195 Wrap/Strip and RC 1 Restricting collar.
 - .4 Damming material: Provide permanent or removable mineral wool, mineral fibreboard, sheet metal, plywood, particleboard, or calcium silicate board to temporarily support firestopping in accordance with tested assembly being installed and as acceptable to authority having jurisdiction.
 - .5 Retainers: 24mm (15/16") wide x 24 ga. steel Z formed configuration with bottom dimensions conforming to opening size listed in manufacturer's sizing chart.
 - .6 Acceptable Manufacturers:
 - .1 AD Fire Protection Systems Inc.
 - .2 Hilti Fire Stop Systems.
 - .3 3M Fire Protection Products.
 - .4 Tremco, Tremstop, Firestop Systems.
 - .5 Rectorseal, Bio Fireshield.

Part 3 Execution

3.1 EXAMINATION

- .1 Verify opening configurations, penetrating items, substrates, and other conditions affecting performance of firestopping are ready to receive the work of this section.

- .2 Do not proceed with installation until unsatisfactory conditions have been corrected.

3.2 PREPARATION

- .1 Clean substrate surfaces of dirt, dust, grease, oil, loose material, or other matter which may affect bond of firestopping material.
- .2 Remove incompatible materials which may affect bond.
- .3 Install backing or damming materials to arrest liquid material leakage.

3.3 APPLICATION

- .1 Apply primer and materials to manufacturer's written instructions.
- .2 Install material at walls or partition openings which contain penetrating sleeves, piping, ductwork, conduit and other items, requiring firestopping.
- .3 Apply firestopping material in sufficient thickness to achieve rating as listed in manufacturer's technical literature and to uniform density and texture. Fire resistance rating of fire stopping material assembly must meet or exceed the fire resistance rating of the floor or wall assembly being penetrated.
- .4 Seal holes or voids made by through penetrations, poke through termination devices, and unpenetrated openings or joints to ensure continuity and integrity of fire separation are maintained.
- .5 Tool or trowel exposed surfaces to a neat finish where required.
- .6 Remove excess compound promptly as work progresses and upon completion.

3.4 CLEANING

- .1 Clean adjacent surfaces of firestopping materials.
- .2 Remove equipment, excess materials and debris and clean adjacent surfaces immediately after application. Use methods and cleaning materials approved by manufacturer.
- .3 Protect firestopping during and after curing period from contact with contaminating substances. If damage caused by others, the Contractor shall instruct the Firestop Sub-Trade to make appropriate repairs and charge to appropriate trades.
- .4 Remove temporary dams after initial set of fire stop and smoke seal materials.

3.5 SCHEDULES

- .1 Jan Closet: 1 hour.
- .2 Electrical/Mechanical Room: 1 hour.

END OF SECTION

Part 1 General

1.1 SECTION INCLUDES

- .1 Preparing substrate surfaces.
- .2 Sealant and joint backing.
- .3 Structural sealant for glazing assemblies.

1.2 RELATED SECTIONS

- .1 Section 07 84 00 – 06 41 11: Architectural Woodwork
- .2 Section 07 84 00 - Firestopping: Sealants required in conjunction with firestopping.

1.3 REFERENCES

- .1 ASTM C509-06 - Elastomeric Cellular Preformed Gasket and Sealing Material.
- .2 ASTM C834-10 - Latex Sealants.
- .3 ASTM C919-08 - Use of Sealants in Acoustical Applications.
- .4 ASTM C920-08 - Elastomeric Joint Sealants.
- .5 ASTM C1184-05 - Structural Silicone Sealants.
- .6 ASTM C1193-09 - Guide for Use of Joint Sealants.
- .7 ASTM C1311-10 - Solvent Release Sealants.
- .8 ASTM C1330-02(2007) - Cylindrical Sealant Backing for Use with Cold Liquid Applied Sealants.
- .9 ASTM C1401-09a - Guide for Structural Sealant Glazing.
- .10 ASTM E330-02 - Test Method for Structural Performance of Exterior Windows, Doors, Skylights and Curtain Walls by Uniform Static Air Pressure Difference
- .11 CGSB-19-GP-5M-1984 - Sealing Compound, One Component, Acrylic Base, Solvent Curing.
- .12 CGSB-19-GP-14M-1984 - Sealing Compound, One Component, Butyl-Polyisobutylene Polymer Base, Solvent Curing.
- .13 CAN/CGSB-19.13-M87 - Sealing Compound, One-component, Elastomeric, Chemical Curing.
- .14 CAN/CGSB-19.17-M90 - One-Component Acrylic Emulsion Base Sealing Compound.
- .15 CAN/CGSB-19.22-M89 - Mildew-Resistant Sealing Compound for Ceramic Tiles.

- .16 CAN/CGSB-19.24-M90 - Multi-component, Chemical Curing Sealing Compound.
- .17 SWRI (Sealant, Waterproofing and Restoration Institute) - Sealant and Caulking Guide Specification.

1.4 SCOPE OF WORK

- .1 Caulking shall be provided where required to prevent entry of water into the structure.
- .2 Caulking shall be provided between masonry, siding, or other cladding materials and the adjacent door and window frames or trim, including sills unless, such locations are completely protected from the entry of water. Caulking shall also be provided at vertical joints between different cladding materials unless the joint is suitably lapped or flashed to prevent the entry of water.
- .3 Caulking shall be provided at all masonry control joints.
- .4 Caulk perimeter of all interior pressed steel door and window frames, fire hose cabinets, access door flanges, etc.

1.5 PERFORMANCE REQUIREMENTS

- .1 Sealant Design: Design structural sealant to withstand specified loads without breakage, loss, failure of seals, product deterioration, and other defects.
- .2 Design installed sealant to withstand:
 - .1 Dead loads and live loads caused by positive and negative wind loads acting normal to plane of wall as calculated in accordance with the National Building Code.
 - .2 Movement from ambient temperature range of 49 degrees C (120 degrees F).
 - .3 Movement and deflection of structural support framing.
 - .4 Water and air penetration.

1.6 ADMINISTRATIVE REQUIREMENTS

- .1 Coordination:
 - .1 Coordinate with other work having a direct bearing on work of this section.
 - .2 Coordinate the work with all sections referencing this section.

1.7 SUBMITTALS FOR REVIEW

- .1 Section 01 33 00: Submittal Procedures
- .2 Product Data: Provide data indicating sealant chemical characteristics, performance criteria, substrate preparation, limitations, colour availability.
- .3 Samples: Submit two (2) samples, 300 mm (12 inch) in size illustrating sealant colours for selection.

1.8 SUBMITTALS FOR INFORMATION

- .1 Section 01 33 00: Submittal Procedures.

- .2 Installation Data: Manufacturer's special installation requirements.
 - .1 Indicate special procedures, surface preparation, perimeter conditions requiring special attention, field quality control testing.

1.9 QUALITY ASSURANCE

- .1 Perform work to sealant manufacturer's requirements for preparation of surfaces and material installation instructions.
- .2 Perform structural sealant application work to ASTM C1401.
- .3 Perform acoustical sealant application work to ASTM C919.
- .4 Manufacturer Qualifications: Company specializing in manufacturing the Products specified in this section with minimum three (3) years documented experience.
- .5 Applicator Qualifications: Company specializing in performing the work of this section with minimum three (3) years documented experience.

1.10 ENVIRONMENTAL REQUIREMENTS

- .1 Maintain temperature and humidity recommended by the sealant manufacturer during and after installation.

1.11 WARRANTY

- .1 Section 01 78 00: Closeout Submittals.
- .2 Warranty: Include coverage for installed sealants and accessories which fail to achieve air tight seal and water tight seal, exhibit loss of adhesion or cohesion, or do not cure.
- .3 Provide manufacturer's twenty (20) year material warranty for installed silicone sealant.
- .4 Defective work shall include, but not be restricted to joint leakage, cracking, crumbling, melting, running, loss of adhesion, loss of cohesion, or staining of adjoining or adjacent work or surfaces.

Part 2 Products

2.1 MATERIALS

- .1 Sealant Colour: to be selected by the Contract Administrator from full range.
- .2 Primers: To be type recommended by sealant manufacturer.
- .3 Joint backing material: shall be extruded polyolefin foam.
 - .1 Standard of Acceptance:
 - .1 Tremco Sof Rod.
- .4 Bond Breaker: Where joint configuration does not allow for proper depth/width ration (See Section 3.2.5) - a pressure sensitive plastic tape, such as 3M #266 or #481 shall be placed on the back of the joint which will not bond to the sealant.

- .5 Joint Cleaner: Xyol, methylethylketone, or non-corrosive type recommended by sealant manufacturer and compatible with joint forming materials.

2.2 SEALANTS

- .1 Type 1: Sealant for all locations except where another type is specified in this section. Multi-component, polyepoxide urethane sealant. To meet specified requirements of CGSB Specification CAN2.19-24-M80.
 - .1 Standard of Acceptance:
 - .1 Tremco Dymeric 511
 - .2 Sonolastic NP-2
 - .3 Permapol RC-2.
 - .4 Morton Thiokol
 - .5 Sikaflex 2CNS/SL
 - .6 Bostik Chem-Calk 500
 - .2 Type 2: Sealant for construction joints in lieu of Type 1 where pre-approved by Contract Administrator. One part elastomeric sealants: to meet specified requirements of NSC/CGSB 25-B-N moisture curing hybrid polyurethane.
 - .1 Standard of Acceptance:
 - .1 Tremco Dymonic.
 - .2 Sonolastic 150.
 - .3 Permapol RC-1.
 - .4 Morton Thiokol.
 - .5 Sikaflex 1A.
 - .6 Bostik Chem-Calk900.
 - .2 Type 3: Sealant for glass to glass, sloped glazing systems, glass to metal, and metal to metal joints. One part low modulus silicone elastomeric sealant to meet specified requirements of NSC/CGSB Specification CAN2-19.13-M82.
 - .1 Standard of Acceptance:
 - .1 Dow Corning 795
 - .2 Tremco Spectrum 2.
 - .3 GE Silglaze 2800.
 - .4 GE Silpruf 2000.
 - .3 Type 4: Polyurethane sealant for exterior and interior horizontal traffic joints.
 - .1 Standard of Acceptance:
 - .1 Tremco THC-900.
 - .2 Permapol RC-2Sl.
 - .3 Sonolastic SL2.
 - .4 Sikaflex 2CSL.
 - .5 Bostik Chem-Calk 550
 - .4 Type 6: Use at all perimeter joints and openings in sound rated drywall systems and sealing polyethylene air/vapour barriers. One part acoustical sealant to meet specified requirements of CGSB Specification 19-GP-21M.

- .1 Standard of Acceptance:
 - .1 Tremco Acoustical sealant.
 - .2 Gibson Homans 2210.
- .5 Type 7: Sealant for finishing interior construction joints subject to minimal movement and not otherwise specified in this section. One part paintable latex.
 - .1 Standard of Acceptance:
 - .1 Tremco Latex 100.
 - .2 Bulldog Acrylic Latex
- .6 Type 8: Sealant for sealing gutters and rainware. One part high quality synthetic rubber blended with a synthetic resin for metal to metal and metal to plastic joints.
 - .1 Standard of Acceptance:
 - .1 Tremco Gutter Seal.
- .2 Type 9: Sealant for masonry joints including control joints, reglets, etc.: Ultra-low modulus, one part silicone joint sealant. 790 or moisture curing hybrid polyurethane 150.
 - .1 Standard of Acceptance:
 - .1 Sonolastic 150.

2.3 STRUCTURAL SEALANT

- .1 Structural Silicone Sealant: ASTM C1184, ASTM C920, Grade NS, Class A, Use NT; single component, neutral curing, non-sagging, non-staining, fungus resistant non-bleeding;
 - .1 Colour: To be selected by Contract Administrator from Standard Colour Range.
 - .2 Elongation Capability 25%.
 - .3 Service Temperature Range -54 to 82 degrees C (-65 to 180 degrees F).
 - .4 Shore A Hardness Range 40.

2.4 ACCESSORIES

- .1 Primer: Non-staining type, recommended by sealant manufacturer to suit application.
- .2 Joint Cleaner: Non-corrosive and non-staining type, recommended by sealant manufacturer; compatible with joint forming materials.
- .3 Joint Backing: ASTM C1330; round, closed cell polyethylene foam rod; oversized 30% to 50% larger than joint width.
- .4 Bond Breaker: Pressure sensitive tape recommended by sealant manufacturer to suit application.
- .5 Masking tape: Non-staining, non-absorbent type compatible with sealant and adjacent surfaces.
- .6 Setting Blocks and Spacers: Compatible with silicone sealant and recommended by sealant manufacturer.

Part 3 Execution

3.1 EXAMINATION

- .1 Section 01 71 00: Verify existing conditions before starting work.
- .2 Verify that substrate surfaces and joint openings are clean, dry, and free of frost and ready to receive work.
- .3 Verify that joint backing and release tapes are compatible with sealant.
- .4 Verify at the Site that joints and surfaces have been provided and that joint conditions will not adversely affect execution, performance, or quality of the completed work; and that they can be put into acceptable condition by means of preparation specified in this section.
- .5 Ascertain that sealers and coatings applied to sealant substrates are compatible with sealant used and that full bond between sealant and substrate is attained. Request samples of the sealed or coated substrate from their fabricators for testing of compatibility and bond, if necessary.
- .6 Verify that specified environmental conditions are ensured before commencing work.
- .7 Ensure that releasing agents, coatings or other treatments have either not been applied to joint surfaces or that they are entirely removed.
- .8 Defective work resulting from application to unsatisfactory joint conditions will be considered the responsibility of those performing the Work of this Section.

3.2 PREPARATION

- .1 Remove loose materials and foreign matter which might impair adhesion of sealant.
- .2 Clean and where required prime joints to sealant manufacturer's written instructions.
- .3 Perform preparation to sealant manufacturer's written instructions.
- .4 Protect elements surrounding the work of this section from damage or disfiguration.
- .5 Remove dust, paint, loose mortar, and other foreign matter and dry joint surfaces.
- .6 Remove dust silt, scale, and coatings from ferrous metals by wire brush, grinding, or sandblasting.
- .7 Remove oil, grease and other coatings from non-ferrous metals with joint cleaner.
- .8 Joints to be caulked are to be a minimum of 6mm (1/4 inch) to a maximum of 40mm (1 1/2 inch). Examine joint sizes to achieve proper width/depth ratio per manufacturer's recommendations for specified sealant.
- .9 Install joint filler or apply bond breaker tape to achieve correct joint depth.
- .10 Where necessary to prevent staining, mask adjacent surfaces with tape prior to priming and/or caulking.

- .11 Prime sides of joints to sealant manufacturer's instructions immediately prior to caulking.
- .12 Before any caulking or sealing is commenced, a test of the material shall be made for indications of staining or poor adhesion.

3.3 INSTALLATION

- .1 Install sealant to sealant manufacturer's written instructions.
- .2 Measure joint dimensions and size materials to achieve required width/depth ratios.
- .3 Install joint backing to achieve a neck dimension no greater than 1/3 of the joint width.
- .4 Install bond breaker where joint backing is not used.
- .5 Install sealant free of air pockets, foreign embedded matter, ridges, and sags.
- .6 Apply sealant within recommended application temperature ranges. Consult manufacturer when sealant cannot be applied within these temperature ranges.
- .7 Tool joints concave unless detailed otherwise.

3.4 STRUCTURAL SEALANT INSTALLATION

- .1 Site install glass panels specified in Section 08 80 50 to aluminum curtain wall framing specified in Section 08 44 13.
- .2 Joint Design: Install sealant as follows:
 - .1 Glueline Thickness: 6 mm (1/4 inch) minimum.
 - .2 Structural Bite: 6 mm (1/4 inch) minimum and equal to or greater than glueline thickness.
 - .3 Fill joint with standard sealant application procedures, install backer rod or bond breaker tape to avoid three-sided sealant adhesion.
- .3 Prepare substrates and apply silicone sealant to manufacturer's written instructions and reviewed Shop Drawings.
- .4 Bond glass to metal support members with structural silicone sealant using 2-sided method as detailed on Drawings.
- .5 Install sealant without gaps, twisting, stretching, or puncturing backing material. Ensure uniform depth to achieve correct profile, coverage, and performance.
- .6 Use temporary glass supports to retain glass panels while sealant is applied and allowed to cure.
- .7 Provide concave, smooth, uniform, sealant finish. Eliminate air pockets and ensure complete contact on both sides of joint opening.

3.5 CLEANING

- .1 Clean adjacent soiled surfaces.

3.6 PROTECTION OF FINISHED WORK

- .1 Remove masking tape and excess sealant.
- .2 Protect sealants until cured , remove temporary glass supports.

END OF SECTION