



## 281-2015ADDENDUM 1

### FORT ROUGE TRANSIT GARAGE COMPRESSED AIR SYSTEM UPGRADE

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: April 24, 2015  
BY: Peter Tataryn  
TELEPHONE NO. (204) 453-2301

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20150105

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph ^8 of Form A: Bid may render your Bid non-responsive.**

---

#### **NMS DIVISION 23**

Revise: Section 23 05 05, 3.4.1 to read: Install automatic drain valve at new **vertical** receiver tank **and AC-01 horizontal receiver tank**.

#### **DRAWINGS**

Replace: 281-2015\_Drawing\_M1-R3 with 281-2015\_Addendum\_1\_Drawing\_M1-R4.

281-2015\_Drawing\_M3-R3 with 281-2015\_Addendum\_1\_Drawing\_M3-R4

281-2015\_Drawing\_E1-R0 with 281-2015\_Addendum\_1\_Drawing\_E1-R1