


- NOTES:
- FIELD ASSEMBLE CHAMBER TO BE WATERTIGHT ALL JOINTS WITH WATERPROOFING
  - MINIMIZE NUMBER OF MANHOLE JOINTS, BASE & FIRST SECTION TO BE 1830mm LONG
  - MINIMUM 1 - 250mm ADJUSTABLE RING
  - PLACE LADDER RUNGS ON OPEN SIDE OF ACCESS HATCH
  - TOP OF MANHOLE TO FIRST LADDER RUNG - MAX. 600mm
  - ALL BOLTS ON FLANGES TO BE STAINLESS STEEL
  - ALL FABRICATED PARTS TO BE GALVANIZED OR STAINLESS STEEL

**AIR RELEASE VALVE AND CHAMBER**

SCALE = 1:25




No.	REVISIONS	DATE	INITIALS	B.M. EL.

LOCATIONS OF UNDERGROUND STRUCTURES/UTILITIES AS SHOWN ARE BASED ON AVAILABLE INFORMATION BUT NO GUARANTEE IS GIVEN OR IMPLIED THAT ALL EXISTING UNDERGROUND STRUCTURES/UTILITIES ARE SHOWN OR THAT THE GIVEN LOCATIONS ARE EXACT. CONFIRMATION OF EXISTENCE AND EXACT LOCATION OF ALL UNDERGROUND STRUCTURES/UTILITIES MUST BE OBTAINED FROM THE APPROPRIATE AUTHORITY/OWNER, BY THE CONTRACTOR, BEFORE PROCEEDING WITH CONSTRUCTION.



ENGINEER'S SEAL  
**PRELIMINARY**



**JR Cousin Consultants Ltd.**  
91A Scurfield Blvd. Winnipeg MB R3Y1G4  
p. (204) 489-0474  
f. (204) 489-0487  
www.jrcc.ca  
ENGINEERING EXCELLENCE SINCE 1981

CODE: W-700.02	PROJECT: CITY OF WINNIPEG - ALTERATIONS TO WATER CIRCULATION SYSTEM FOR WESTDALE SPLASH PAD
DESIGNED BY: RO	TITLE: WESTDALE POOL SPLASH PAD MODIFICATIONS - MANHOLE DETAILS
DRAWN BY: RO	BID OPPORTUNITY NO. 387-2015
REVIEWED BY: JD	SCALE: 1:25 DATE: 15/04/22 PLAN: D1 SHEET: 7 of 7