



Labour and Immigration



INSPECTION AND TECHNICAL SERVICES MB  
508 - 401 YORK AVENUE,  
WINNIPEG, MB R3C 0P8  
PHONE (204) [REDACTED] FAX (204) [REDACTED]  
HTTP://FIRECOMM.GOV.MB.CA/ITSM\_MAIN.HTML

CITY OF WINNIPEG CORP FINANCE  
4TH FLR.,510 MAIN ST.,  
WINNIPEG, MB R3B 1B9

[REDACTED]  
MB Elevator # 3615  
Elevator Type: UNKNOWN TYPE  
Location : MAIN & PORTAGE  
CONCOURSE  
N E RICHARDSON CORNER  
WINNIPEG

The Elevating Device located at : N E RICHARDSON CORNER, in the City of WINNIPEG, was inspected on [REDACTED], by our Inspector [REDACTED].

The following conditions were observed that require attention at this time:

Access into machine space from access hole in wall to be closed off (locked <sup>and</sup> ~~in~~ signage)

[REDACTED] machine room and pit light and receptical be operational

Walk on plate to be replaced or repaired

The above instructions must be completed by [REDACTED] and the above Branch notified accordingly.

**Please notify our office in writing when the work orders have been completed.**

It is the owner's responsibility to inform our Branch of all changes regarding management and ownership and possession date in order that our record may be amended accordingly.

If you have any questions regarding this report, please contact me at (204) [REDACTED]

Report Submitted by:

[REDACTED]  
Inspection and Technical Services MB  
Phone number : (204) [REDACTED]  
Fax number : [REDACTED]  
Email : [REDACTED]