



PARTIAL MAIN FLOOR PLAN - FIRE PROTECTION REVISION
SCALE: 3/16"=1'-0"

LEGEND (SUPPLY & INSTALL UNLESS OTHERWISE INDICATED) DASHED LINE INDICATES DEMOLITION	
TYPE	DESCRIPTION
⊗	SPRINKLER HEAD (EXIST) QUICK RESPONSE SEMI-RECESSED CHROME PENDENT SPRINKLER 155°F (68°C), 1/2" ORIFICE, K=5.6
⊙	SPRINKLER HEAD (NEW) QUICK RESPONSE SEMI-RECESSED CHROME PENDENT SPRINKLER 155°F (68°C), 1/2" ORIFICE, K=5.6
⊗ P	SPRINKLER HEAD (REMOVE AND PLUG OUTLET) QUICK RESPONSE SEMI-RECESSED CHROME PENDENT SPRINKLER 155°F (68°C), 1/2" ORIFICE, K=5.6
⊗ R	SPRINKLER HEAD (REMOVE AND RELOCATE) QUICK RESPONSE SEMI-RECESSED CHROME PENDENT SPRINKLER 155°F (68°C), 1/2" ORIFICE, K=5.6

- MAIN FLOOR PLAN RENOVATION NOTES:**
- 1 SUPPLY & INSTALL NEW SPRINKLER HEADS - MATCH EXISTING CONNECT TO EXISTING SPRINKLER BRANCH LINES AS REQUIRED
 - 2 RELOCATE EXISTING SPRINKLER HEADS AS SHOWN - TYPICAL
 - 3 REMOVE SPRINKLER HEAD AND PLUG EXISTING OUTLET
 - 4 VISUALLY INSPECT EXISTING SPRINKLER HEADS AND CLEAN AS REQUIRED IN AREAS BEING RENOVATED

NOTES:
THESE DRAWINGS SHALL NOT BE SCALED.
THE CONTRACTOR SHALL VISIT THE SITE AND SATISFY HIMSELF ALL DIMENSIONS, DATUM, AND DETAILED INFORMATION SHOWN ARE CORRECT.
THE CONTRACTOR IS TO REVIEW AND COORDINATE ALL ARCHITECTURAL, MECHANICAL, ELECTRICAL AND STRUCTURAL DRAWINGS FOR ADDITIONAL OPENINGS THROUGH FLOORS, WALLS, AND CEILINGS FOR DUCT, PIPE & ELECTRICAL RISERS AND ALL OPENINGS NOT SHOWN ON DRAWINGS.
ALL OPENINGS THROUGH FIRE ASSEMBLIES ARE TO BE FIRE STOPPED AND SEALED WITH ULC APPROVED FIRE STOPPING TO MAINTAIN THE INTEGRITY OF THE FIRE SEPARATION, AND PROVIDE A SMOKE-TIGHT BARRIER.
ALL PRODUCTS AND MATERIALS TO BE USED AND INSTALLED SHALL CONFORM WITH MANUFACTURER'S SPECIFICATIONS & APPLICABLE CODES.
THE CONTRACTOR SHALL BE RESPONSIBLE TO PATCH AND MAKE GOOD ALL EXISTING CONSTRUCTION AFFECTED BY THE REMOVAL OF ALL ITEMS FORMING THE PART OF THE RENOVATION WORK.
THE CONTRACTOR IS RESPONSIBLE FOR INSTALLING RISERS, SWING JOINTS AND DEEP CUP ESCUTCHEONS AS REQUIRED.
COMPLETE ALL WORK IN CONFORMANCE WITH THE REQUIREMENTS OF NFPA 13-2013 'STANDARD FOR THE INSTALLATION OF SPRINKLER SYSTEMS'.

0	ISSUED FOR CONSTRUCTION	JAW	AUG 21 2015
No.	REVISION/DESCRIPTION	BY	DATE



DRAWN	CHECKED	DESIGNED	APPROVED
DATE 2015.08.21	USER APPROVAL		

THE CITY OF WINNIPEG
PLANNING, PROPERTY AND DEVELOPMENT DEPARTMENT
MUNICIPAL ACCOMMODATIONS DIVISION
3-65 GARRY STREET, R3C 4K4

PROJECT
RICE BUILDING
CITY OF WINNIPEG
PARKING AUTHORITY
491 PORTAGE AVE.

SHEET TITLE
MAIN FLOOR PLAN
FIRE PROTECTION REVISION

SCALE AS SHOWN	PROJECT No: 2013-127	SHEET No: F1
-------------------	-------------------------	-----------------