



FUSE SCHEDULE			
TB	IDENTIFIER	SIZE	RATED CURRENT (A)
TB03	1P	5x20mm	0.2
	2P	5x20mm	0.2
	3P	5x20mm	0.2
	4P	5x20mm	0.2
	5P	5x20mm	0.2
	6P	5x20mm	0.2
	7P	5x20mm	0.2
	8P	5x20mm	0.2
	9P	5x20mm	0.2
	19P	5x20mm	0.2
	11P	5x20mm	0.2
	12P	5x20mm	0.2
	13P	5x20mm	0.2
	14P	5x20mm	0.2
	15P	5x20mm	0.2
	16P	5x20mm	0.2

LEGEND:

DOUBLE LEVEL FUSED TERMINAL
 ANNUNCIATOR PANEL LIGHT

DRAWING NUMBER	REFERENCE DRAWINGS



NO.	REVISIONS	DATE	DESIGN	CHECK
00	ISSUED FOR TENDER	2015/09/17	BJC	-

SNC-LAVALIN INC.
 148 Nature Park Way
 Winnipeg, MB, Canada R3P 0X7
 204-786-8080

DESIGNED BY: B. CLEVEN
 CHECKED BY:
 DRAWN BY: C. BURZYNSKI
 APPROVED BY:
 SCALE: NTS
 ISSUED FOR CONSTRUCTION
 DATE: 2015/08/06
 BY:
 DATE:

CONSULTANT NO.:

ENGINEER'S SEAL
PRELIMINARY
NOT TO BE USED FOR CONSTRUCTION

THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT

OLIVE WASTEWATER PUMPING STATION
 2015 UPGRADES
 RTU I/O WIRING DIAGRAM
 CONTROL PANEL CP-LB1
 DISCRETE INPUTS 10001-10016

CITY DRAWING NUMBER: 1-0169L-A0003
 SHEET: 001
 REV.: 00
 SIZE: A1