



NOTES

- * CITY OF WINNIPEG TO SUPPLY EQUIPMENT CONTRACTOR TO INSTALL.
- 1. PROVIDE INSULATION/ VAPOUR PROTECTION FOR MIN. 3.0m BEFORE AN EXTERIOR WALL PENETRATION.
- 2. DIRECT 13mm DRAIN DISCHARGE PIPING TO THE NEAREST FLOOR DRAIN.



| | | | |
|--|----------------------------|---------------------------|-----|
| B.M. ELEV. | | | |
| CONSTRUCTION COMPLETION DATE: YYYY MM DD | | | |
| DESIGNED BY | KG | CHECKED BY | BW |
| DRAWN BY | JBC | APPROVED BY | BW |
| SCALE: | | RELEASED FOR CONSTRUCTION | |
| 1 | ISSUED FOR BID OP. 85-2015 | 15/02/10 | JBC |
| 0 | ISSUED FOR TENDER | 14/06/13 | JBC |
| NO. | REVISIONS | DATE | BY |
| | | 2015 02 10 | |

CH2MHILL

DESIGNED BY: KG, CHECKED BY: BW, DRAWN BY: JBC, APPROVED BY: BW, SCALE: HORIZONTAL NTS, VERTICAL -

DATE: 2015 02 10

ENGINEER'S SEAL: PROVINCE OF MANITOBA, S.A.R. BEGG, Member 23747, Registered Professional Engineer, Feb 18, 2015

CONSULTANT DRAWING NUMBER: WX-H0001

THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION

CITY OF WINNIPEG WATER TREATMENT RESEARCH AND PROCESS OPTIMIZATION FACILITY HVAC AIR FLOW SCHEMATIC

SHEET X OF X, CITY DRAWING NUMBER: 1-0601X-H0001-001-01