



- GENERAL NOTES:**
- FOR CONCRETE FINISHES SEE SPECIFICATIONS
 - SEE DETAILS (0315-803), (0330-004) & (0330-812)
 - 1000mm WIDE MIN TYPE 2 CRUSHED ROCK COMPACTED TO 98% SPMD IN MAXIMUM LIFTS OF 300mm AGAINST WALL.
 - BACKFILL THE AREA WITH SELECT ONSITE FILL COMPACTED TO 98% SPMD IN MAXIMUM LIFTS OF 300mm.
 - 300mm THICK GEOFOAM TYPE EPS 15 OR EQUAL ON TOP OF SLAB WITH MAXIMUM 300mm EARTH COVER ON TOP OF GEOFOAM, TYPICAL OVER ENTIRE ROOF SLAB UNLESS NOTED OTHERWISE. PROVIDE 60 MIL PVC SHEET ON TOP OF GEOFOAM OVER ENTIRE FOOTPRINT, TAPE ALL SEAMS. EXTEND UP AND DOWN FROM WALL/SLAB/CURB INTERSECTIONS 1300mm ALL AROUND.
 - PROVIDE WEEPING TILE SYSTEM ALL AROUND. SEE DWG CGAD-S001 FOR LAYOUT AND DETAILS.
 - WHERE THE EXCAVATION LINE IS LOCATED BELOW THE UNDERSIDE OF THE VOID FORM, FILL THE AREA WITH CLASS 4 BACKFILL COMPACTED TO 98% SPMD.

C SECTION - PART C
1:50

SGAD-S001, SGAD-S004,
SGAD-S005, SGAD-S006,
SGAD-S009, SGAD-S010,
SGAD-S011, SGAD-S014,
SGAD-S015, SGAD-S016,
SGAD-S017, SGAD-S018



DESIGNED BY: A. THAKKAR		CHECKED BY: E. LUI		APPROVED BY: H.T. FREIHAMMER		SOUTH END WATER POLLUTION CONTROL CENTRE SEWPC UPGRADING/EXPANSION PROJECT STRUCTURAL SECONDARY CLARIFIERS 4 AND 5 SECTION C - PART C	
DRAWN BY: G. OMORI		SCALE: 1:50		ISSUED FOR CONSTRUCTION BY: T. TURZAK		CITY DRAWING NUMBER 1-0102-SGAD-S023	
DATE: 2016/01/29		DATE: 2016/01/29		CONSULTANT NO.: 474248		SHEET REV. SIZE 001 01 A1	
01 ISSUED FOR ADD. 2 - B.O. 899-2015		02/2016 G.O. J.C.		00 ISSUED FOR TENDER - B.O. 899-2015		01/2016 G.O. J.C.	
NO. REVISIONS		DATE DESIGN CHECK		PLOT DATE: 2/24/2016		FILE NAME: 1-0102-SGAD-S023.dgn	