



## 952-2015 ADDENDUM 2

### NORTH END SEWAGE TREATMENT PLANT (NEWPCC) HAULED LIQUID WASTE FACILITY PHASE II UPGRADE

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY**

ISSUED: March 24, 2016  
BY: Rob Gillis  
TELEPHONE NO. (204) 489-5900

**THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS**

Template Version: A20150806

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.**

---

#### **PART D – SUPPLEMENTAL CONDITIONS**

Revise: D4.1 to read: The Contract Administrator is Stantec Consulting, Ltd., represented by:

Rob Gillis, P. Eng.  
Senior Project Manager

Telephone No. 204 489 5900  
Email: [rob.gillis@stantec.com](mailto:rob.gillis@stantec.com)

#### **PART E – SPECIFICATIONS**

Add: Section 22 42 00, Clause 2.1 Franke Kindred to the list of acceptable manufacturers for the sink

Delete: Section 22 42 00, Clause 2.2.1

Replace: Section 22 42 00, Clause 2.4 with the following

**2.4 COUNTER TOP SINGLE SINK**

- .1 Single bowl ledgeback sink, 305 mm (12") deep, 20 gauge, 18-8 stainless steel, 3 hole, #4 commercial satin finish, fully undercoated. Basket strainer waste fitting and installation kit included.
- .2 Two handle centerset gooseneck faucet, brass construction, polished chrome finish, brass valve bodies, quarter turn washerless ceramic disc valves, assuring positive handle stop positioning. SS lever handles, drain and lift rod, 1.9 lpm (0.5 gpm) vandal resistant aerator spray head, appropriate mounting hardware included.