

1005-2016 ADDENDUM 2

FORT ROUGE TRANSIT BASE STORAGE TRACK 1-12 VENTILATION UPGRADE

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: December 9, 2016
BY: Jeff Horrocks, P.Eng.
TELEPHONE NO. 204-789-2332

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

- Revise: 1.2.6.12 of 21 05 10 to read: Triple duty valves* Armstrong; B&G; Gruvlok; Victaulic; Taco
- Revise: 1.2.6.13 of 21 05 10 to read: Suction guides* Armstrong; B&G; Taco
- Revise: 2.4.1 of 22 40 10 to read: Roof hydrants: Zurn Z1388, exposed, non-freeze roof hydrant, with Dura-Coated cast iron head and lift handle with lock option, bronze interior parts, galvanized steel casing, and bronze housing with 1/8" (3mm) IP drain port in housing. Complete with Dura-Coated cast iron roof support sleeve with wide anchoring flange and clamp collar. 3/4" (19mm) adapter vacuum breaker.
- Add: 3.7 to 22 40 10 to read: Roof hydrants: Install roof hydrant as per manufacturers standard instructions as well as the following:
- Drain port in housing shall be capped or removed.
 - Provide curb or inlet wood blocking within roof around roof hydrant in addition to specified clamping collar as required to provide rigid connection to roof.
 - Seal penetration water tight with sopramastic block system (detail RD-1).
- Add: 1005-2016_Addendum_2-NMS_Detail_RS-2