



1044-2016 ADDENDUM 3

SEVEN OAKS POOL ADDITION & RENOVATION

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: January 04, 2017
BY: Damien Fenez
TELEPHONE NO. 204 956 0938

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20150806

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: Division 087120 Item 2.2.8.2 to read:

Power assist and low energy power operated doors to CAN/CGSB-69.35: single door operation with actuators, electric strikes, control boxes, and all related hardware. Surface mounted type with ability to adjust operation speed. Where Norton 6000 series auto door operators are scheduled in Section 080671 Hardware Sets, other acceptable products are: LCN 4642, Horton 4100HD, Gyro-Tech GT-500, Besam SW200i, Stanley Magic Swing, or Ditec Entrematic HA-8. Where Norton 5700 series auto door operators are scheduled in Section 080671 Hardware Sets, other acceptable products are: Horton 7100 series, Gyro-Tech GT710 or any of listed operators above.

Revise: Division 090600 Room Finish Schedule

Delete reference to EM in floor finish column for room 100 Vestibule

DRAWINGS

Replace: 1044-2016 _Drawing_A4-05-R0 with 1044-2016 _Addendum_3-Drawing_A4-05-R1

Replace: 1044-2016 _Drawing_E0-02-R0 with 1044-2016 _Addendum_3-Drawing_E0-02-R1

END OF 1044-2016_ADDENDUM 3