



129-2016 ADDENDUM 2

WINDSOR PARK LIBRARY

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: April 27, 2016
BY: Hélio Rodrigues
TELEPHONE NO. 204-774-0012

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20150806

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

REVISE B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, Tuesday May 3, 2016.

PART D – SUPPLEMENTAL CONDITIONS

REVISE D10.1(c) to read:

“(c) Contractors Pollution Liability (CPL) insurance in the amount of at least two million dollars (\$2,000,000) per occurrence and two million dollars (\$2,000,000) aggregate covering third party injury and property damage claims, including clean-up costs and transported cargo as a result of pollution conditions arising from the Contractor’s operations and completed operations. Such policy shall name the City as an additional insured and remain in place for a minimum of twenty-four (24) months following Total Completion Date.”

PART E – SPECIFICATIONS

- REVISE** Section 05 31 00 – Steel Decking, subsection 2.3 Types of Decking, to read
- “1. Steel roof deck over space frame: 18 gauge, 1 1/2” profile, as per structural drawings
 2. Steel roof deck over joists: 22 gauge, 1 1/2” profile, as per structural drawings
 3. Canopy steel roof deck: 22 gauge, 3” profile, as per structural drawings.”
- DELETE** Section 08 80 50 – Glazing, delete clause 2.1.3.1.5 in regards to insulating glass units with Matelux
- REVISE** Section 08 80 50 – Glazing, add clause 2.1.4.1.1, to read “Matelux acid etched glass finish between 110 library services and 107 corridor”
- REVISE** Section 26 51 13 – Interior Luminaires, clause 2.4.1, to read “Exit signs shall be pictogram style, equal to Lumacell LDE series die-cast aluminum edge-lit sign. Confirm number of faces and directional arrows with plans. Provide flat trim for ceiling mount applications. Provide circular trim for wall mount applications. Circular trim shall be recessed where possible.”

DRAWINGS

REPLACE 129-2016_Addendum_1-Drawing_A105-R1 with 129-2016_Addendum_2-Drawing_A105-R2

REPLACE 129-2016_Drawing_A502-R0 with 129-2016_Addendum_2-Drawing_A502-R1

REPLACE 129-2016_Drawing_C100-R0 with 129-2016_Addendum_2-Drawing_C100-R1

REPLACE 129-2016_Drawing_S1-R0 with 129-2016_Addendum_2-Drawing_S1-R1

APPROVED PRODUCT EQUALS

Section 08 71 00 – Door Hardware, 3.6 Schedule

Product Specified:

LCN 9542 Auto Operator

LCN 9131 Auto Operator

Dorma ED400 IG Auto Operator

Approved Equal Granted:

Besam SW200i Auto Operator

Horton 4100LE Auto Operator

Nabco GT8500 Auto Operator

Besam SW100 Auto Operator

Horton 7100 Auto Operator

Nabco GT710 Auto Operator

Besam SW200i-IG Auto Operator

Section 09 91 00 – Painting

Product Specified:

2.1.1 Benjamin Moore

Approved Equal Granted:

Sherwin-Williams