



## 304-2016-ADDENDUM 01

### WINNIPEG TRANSIT GARAGE, 421 OSBORNE STREET 2016 CENTRAL TRENCH AND ADJACENT SLAB REPAIRS

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: 2016-04-20  
BY: Iouri Minenkov  
TELEPHONE NO. 204 943-7501

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20150806

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.**

---

#### **PART E – SPECIFICATIONS**

Add: Division 03, Section 03 92 10, Part 2, Item 2.2.3.2.3 "Vocomp-25 manufactured by W.R. Meadows, at a minimum application rate of 7.35 m<sup>2</sup>/L."

Add: Division 03, Section 03 99 10, Part 2, Item 2.3.4.2.3 "Vocomp-25 manufactured by W.R. Meadows, at a minimum application rate of 7.35 m<sup>2</sup>/L."