



FUSE SCHEDULE			
TB	IDENTIFIER	SIZE	RATED CURRENT (A)
TB03	81P	5x20mm	0.2
	82P	5x20mm	0.2
	83P	5x20mm	0.2
	84P	5x20mm	0.2
	85P	5x20mm	0.2
	86P	5x20mm	0.2
	87P	5x20mm	0.2
	88P	5x20mm	0.2
	89P	5x20mm	0.2
	90P	5x20mm	0.2
	91P	5x20mm	0.2
	92P	5x20mm	0.2
	93P	5x20mm	0.2
	94P	5x20mm	0.2
	95P	5x20mm	0.2
	96P	5x20mm	0.2

**LEGEND:**

DOUBLE LEVEL FUSED TERMINAL

ANNUNCIATOR PANEL LIGHT  
(NOTE: CONNECTION TO COMMON NOT SHOWN. SEE DRAWING 1-0127A-A0002 FOR CONNECTION)

LAST SAVE: 2016/05/06 - 3:16pm  
 PATH: M:\632354\MENG\481&C\DD - General DWG\1-0127A-A0008-001-00.dwg

DRAWING NUMBER	REFERENCE DRAWINGS



NO.	REVISIONS	DATE	DESIGN	CHECK
00	ISSUED FOR TENDER, BID OP. 331-2016	2016/05/05	BJC	FA

**SNC-LAVALIN INC.**  
 148 Nature Park Way  
 Winnipeg, MB, Canada R3P 0X7  
 204-786-8080

DESIGNED BY: B. CLEVEN  
 CHECKED BY: F. ATAEI  
 DRAWN BY: Y. KONIG  
 APPROVED BY: I. PARKINSON  
 SCALE: NTS  
 ISSUED FOR CONSTRUCTION BY: K. ZUREK  
 DATE: 2016/02/03  
 DATE: 2016/05/06

CONSULTANT NO.:

ENGINEER'S SEAL

ORIGINAL DRAWING  
 SEALED BY:  
 B. CLEVEN  
 SNC-LAVALIN  
 MEMBER #31479  
 2016/05/05  
 REV. 00

**THE CITY OF WINNIPEG**  
 WATER AND WASTE DEPARTMENT

COCKBURN FLOOD AND WASTEWATER PUMPING STATION  
 2016 UPGRADES  
 RTU I/O WIRING DIAGRAM  
 CONTROL PANEL CP-A81  
 DISCRETE INPUTS I81-I96

CITY DRAWING NUMBER: 1-0127A-A0008  
 SHEET: 001  
 REV: 00  
 SIZE: A1