



NOTE: ANALOG OUTPUT POWER IS SOURCED FROM THE SCADAPACK INTERNAL POWER SUPPLY, WHICH IS POWERED FROM FUSE TB02-FU04.

SEE DRAWING 1-0127A-A0005 FOR POWER SUPPLY CONNECTION.



NO.	REVISIONS	DATE	DESIGN	CHECK
00	ISSUED FOR TENDER, BID OP. 331-2016	2016/05/05	BJC	FA

 SNC-LAVALIN INC. 148 Nature Park Way Winnipeg, MB, Canada R3P 0X7 204-786-8080		ENGINEER'S SEAL ORIGINAL DRAWING SEALED BY: B. CLEVEN SNC-LAVALIN MEMBER #31479 2016/05/05 REV. 00
DESIGNED BY: B. CLEVEN DRAWN BY: Y. KONIG SCALE: NTS DATE: 2016/02/03	CHECKED BY: F. ATA EI APPROVED BY: I. PARKINSON ISSUED FOR CONSTRUCTION BY: K. ZUREK DATE: 2016/05/06	CONSULTANT NO.:

THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT

 COCKBURN FLOOD AND WASTEWATER PUMPING STATION
 2016 UPGRADES
 RTU I/O WIRING DIAGRAM
 CONTROL PANEL CP-AB1
 ANALOG OUTPUTS AQ1-AQ4

 CITY DRAWING NUMBER
1-0127A-A0013

SHEET	REV.	SIZE
001	00	A1