


LAST SAVE: 2016/05/09 - 8:10am
 PATH: M:\632354\4ENG\48&C\DD - General DWG\1-0127A-A0018-001-00.dwg
 B SIZE - 279mm x 432mm

FIELD

CONTROL PANEL CP-A81



ALARM SETPOINTS	TEMP (°C)
HIGH TEMPERATURE	35°C
LOW TEMPERATURE	4°C

NOTES:
 1. PROVIDE AND INSTALL NEW TEMPERATURE SWITCH.



SNC-LAVALIN INC.
 148 Nature Park Way
 Winnipeg, MB, Canada R3P 0X7
 204-786-8080

ENGINEER'S SEAL

ORIGINAL DRAWING
 SEALED BY:
 B. CLEVEN
 SNC-LAVALIN
 MEMBER # 31479
 2016/05/06
 REV. 00



THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT

COCKBURN FLOOD AND WASTEWATER PUMPING STATION
 2016 UPGRADES
 LOOP DIAGRAM
 ELECTRICAL ROOM HIGH/LOW TEMPERATURE
 TS-A653

NO.	REVISIONS	DATE	DESIGN	CHECK
00	ISSUED FOR TENDER, BID OP. 331-2016	2016/05/05	BJC	FA

DESIGNED BY: B. CLEVEN	CHECKED BY: F. ATAEI
DRAWN BY: Y. KONIG	APPROVED BY: I. PARKINSON
SCALE: NTS	DATE: 2016/03/17
ISSUED FOR CONSTRUCTION BY: K. ZUREK	DATE: 2016/05/06
CONSULTANT NO.:	

CITY DRAWING NUMBER	SHEET	REV.	SIZE
1-0127A-A0018	001	00	B