



# Analysis for Lead Concentration in Paint Chips

by Flame Atomic Absorption Spectroscopy  
EPA SW-846 3050B/6010C/7420



**Customer:** Pinchin Ltd.  
54 Terracon Place  
Winnipeg, MB R2J 4G7

**Attn:** Colleen Uminga

**Lab Order ID:** 1611569  
**Analysis ID:** 1611569\_PBP  
**Date Received:** 6/13/2016  
**Date Reported:** 6/16/2016

**Project:** City of Winnipeg 1887 Pacific Avenue, Winnipeg, Manitoba

Sample ID	Description	Mass (g)	Concentration (ppm)	Concentration (% by weight)
Lab Sample ID	Lab Notes			
1	Paint chips - stripe	0.0534	< 75	< 0.007%
1611569PBP_1				
2	Paint chips - tank	0.0649	< 62	< 0.006%
1611569PBP_2				

Unless otherwise noted blank sample correction was not performed on analytical results. Scientific Analytical Institute participates in the AIHA ELPAT program. ELPAT Laboratory ID: 173190. This report relates only to the samples tested and may not be reproduced, except in full, without the written approval of SAI. Analytical uncertainty available upon request. The quality control samples run with the samples in this report have passed all EPA required specifications unless otherwise noted. RL: (Report Limit for an undiluted 50ml sample is 4µg Total Pb).

Daniel Olson (2)

Analyst

Scientific Analytical Institute, Inc. 4604 Dundas Dr. Greensboro, NC 27407 (336) 292-3888

Laboratory Director

1611569

**Client:** Pinchin Ltd.  
**Contact:**  
**Address:** 54 Terracon Place, Winnipeg, MB  
 R2J 4G7  
**Phone:** 204 452-0983  
**Fax:**  
**Email:** [cuminga@pinchin.com](mailto:cuminga@pinchin.com)  
**Project:** City of Winnipeg  
 1887 Pacific Avenue  
**Client Notes:** Winnipeg, Manitoba  
**P.O. #:**  
**Date Submitted:** 6/9/2016  
**Analysis:** Lead  
**TurnAroundTime:** 4 Day

**Instructions:**  
 Use Column "B" for your contact info  
  
 To See an Example Click the  
 bottom Example Tab.  
  
 Enter samples between "<<" and ">>"  
 Begin Samples with a "<<" above the first sample  
 and end with a ">>" below the last sample.  
 Only Enter your data on the first sheet "Sheet1"  
  
 Note: Data 1 and Data 2 are optional  
 fields that do not show up on the official  
 report, however they will be included  
 in the electronic data returned to you  
 to facilitate your reintegration of the report data.

Scientific  
 Analytical  
 Institute



4604 Dundas Dr.  
 Greensboro, NC 27407  
 Phone: 336.292.3888  
 Fax: 336.292.3313  
 Email: [lab@sailab.com](mailto:lab@sailab.com)

Sample Number	Data 1 (Lab use only)	Sample Description	Data 2 (Lab use only)
1		Paint Chips - Stripe	
2		Paint Chips - Tank	
		Maximo P1-06	

Rejected

Shelton 6/13 12P



# Analysis for Lead Concentration in Paint Chips

by Flame Atomic Absorption Spectroscopy  
EPA SW-846 3050B/6010C/7420



**Customer:** Pinchin Ltd.  
54 Terracon Place  
Winnipeg, MB R2J 4G7

**Attn:** Rodney Legault

**Lab Order ID:** 1612373  
**Analysis ID:** 1612373\_PBP  
**Date Received:** 6/24/2016  
**Date Reported:** 6/27/2016

**Project:** 112108 - 1887 Pacific

Sample ID	Description	Mass (g)	Concentration (ppm)	Concentration (% by weight)
Lab Sample ID	Lab Notes			
1	White paint chip - pool tank bottom	0.0604	< 66	< 0.007%
1612373PBP_1				

Unless otherwise noted blank sample correction was not performed on analytical results. Scientific Analytical Institute participates in the AIHA ELPAT program. ELPAT Laboratory ID: 173190. This report relates only to the samples tested and may not be reproduced, except in full, without the written approval of SAI. Analytical uncertainty available upon request. The quality control samples run with the samples in this report have passed all EPA required specifications unless otherwise noted. RL: (Report Limit for an undiluted 50ml sample is 4µg Total Pb).

Taylor Davis (1)

Analyst

Scientific Analytical Institute, Inc. 4604 Dundas Dr. Greensboro, NC 27407 (336) 292-3888

Laboratory Director

1612373

Version 1-15-2012

**Client:** Pinchin Ltd.  
**Contact:** Rodney Legault  
**Address:** 54 Terracon Place Winnipeg, MB  
**Phone:** 204-452-0983  
**Fax:**  
**Email:** rlegault@pinchin.com  
  
**Project:** 112108 - 1887 Pacific  
**Client Notes:** [Enter Client Notes Here]  
  
**P.O. #:**  
**Date Submitted:** 6/22/2016 0:00  
  
**Analysis:** Lead  
**TurnAroundTime:** Rush

**\*Instructions:**  
 Use Column "B" for your contact info  
  
 To See an Example Click the  
 bottom Example Tab.  
  
**Enter samples between "<<" and ">>"**  
**Begin Samples with a "<<" above the first sample**  
**and end with a ">>" below the last sample.**  
**Only Enter your data on the first sheet "Sheet1"**  
  
 Note: Data 1 and Data 2 are optional  
 fields that do not show up on the official  
 report, however they will be included  
 in the electronic data returned to you  
 to facilitate your reintegration of the report data.

**Invoice to:**  
 Contact name here  
 Email address here

Scientific  
 Analytical  
 Institute



**4604 Dundas Dr.**  
**Greensboro, NC 27407**  
**Phone: 336.292.3888**  
**Fax: 336.292.3313**  
**Email: lab@sailab.com**

Sample Number	Data 1 (Lab use only)	Sample Description	Data 2 (Lab use only)
---------------	-----------------------	--------------------	-----------------------

<<		White Paint Chip - Pool Tank Bottom	
>>			

Accepted

Rejected

Delator 6/24  
 8:30 A