



593-2016 ADDENDUM 1

REQUEST FOR PROPOSAL FOR PROFESSIONAL CONSULTING SERVICES FOR THE NORTH END SEWAGE TREATMENT PLANT (NEWPCC) RETURN ACTIVATED SLUDGE PIPE CONDITION ASSESSMENT AND PRELIMINARY DESIGN

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE REQUEST FOR PROPOSAL

ISSUED: August 2, 2016
BY: Bronwyn Jones
TELEPHONE NO. 204 - 986-8664

THIS ADDENDUM SHALL BE INCORPORATED INTO THE REQUEST FOR PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: Ar20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Request for Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Proposal may render your Proposal non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

- | | |
|---------------|---|
| Add: D4.2.1 | This project is not part of the North End Sewage Treatment Plant Upgrade project and no deliverables from this project are tied to the Upgrade project. |
| Add: D4.6 | The max pressure at the shut-off head of the RAS pumps is 16.0 m of head (23.2 psi). |
| Add: D5.8.1.1 | The consultant shall assume that the RAS pipe will be decommissioned in 10 years. |