

SUPPLY: 208V 3Ø 4W MAINS AMPACITY: 600 INCOMING: <input type="checkbox"/> BREAKER <input checked="" type="checkbox"/> LUGS MAIN BREAKER REQUIRED: <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO MAIN BREAKER AMPS: BUS MATERIAL: <input checked="" type="checkbox"/> COPPER <input type="checkbox"/> ALUMINUM BUS AND BREAKER RATING: 18kA										NAME PLATE: PANEL ' SP-1 '										LOCATION: CRAWLSPACE ELECTRICAL ROOM MOUNTING: <input checked="" type="checkbox"/> SURFACE <input type="checkbox"/> FLUSH MANUFACTURER: MODEL NO: BREAKER: <input type="checkbox"/> PLUG-IN <input checked="" type="checkbox"/> BOLT-ON SPD: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO SERVICE ENTRANCE RATED: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO																			
REV/CCT	VA	P	BKR	A	B	C	BKR	P	VA	CCT/REV	VA	P	BKR	A	B	C	BKR	P	VA	CCT/REV	VA	P	BKR	A	B	C	BKR	P	VA	CCT/REV	VA	P	BKR	A	B	C	BKR	P	VA
1	1000	2	15				15	2	2250	2	1200	1	15				15	1	1050	68	67	C-3	CHEMICAL FEED PUMP	1200	1	15				15	1	1050	68	68					
3										4	1200	1	15				15	1	1050	70	69	C-4	CHEMICAL FEED PUMP	1200	1	15				15	1	1050	70	70					
5										6	1200	1	15				15	1	191	72	71	L-1	WATER LEVELLER SPLASH PAD	1200	1	15				15	1	191	72	72					
7	4000	3	25				15	2	2250	8	1200	1	15				15	1	207	74	73	L-2	WATER LEVELLER POOL	1200	1	15				15	1	207	74	74					
9										10	1200	1	15				15	1	93	76	75	T-SLOT	RECEPTACLES - SWIMSUIT DRYER	1200	1	20				15	1	93	76	76					
11										12	1200	1	20				15	1	1021	78	77	T-SLOT	RECEPTACLES - SWIMSUIT DRYER	1200	1	20				15	1	1021	78	78					
13	600	1	15				15	2	2250	14	1200	1	20				15	1	750	80	79	T-SLOT	RECEPTACLES - SWIMSUIT DRYER	1200	1	20				15	1	750	80	80					
15	1200	1	15				15	2	2250	16							15	1	1000	82	81	SPARE										82	82						
17	1200	1	15				15	2	2250	18							15	1	650	84	83	SPARE										84	84						
19	1200	1	15				15	2	2250	20							15	1	750	86	85	SPARE										86	86						
21	1000	2	15				60	3	8750	22							15	1	1200	88	87	PP-1	SPRAY PAD CIRC PUMP										88	88					
23										24							15	1	3200	90	89	SPARE										90	90						
25	1000	2	15				60	3	8750	26							15	1	600	92	91	SPARE										92	92						
27										28							15	1		94	93	SPARE										94	94						
29	1000	2	15				60	3	8750	30							15	1		96	95	SPARE										96	96						
31										32							15	1		98	97	SPARE										98	98						
33	1000	2	15				40	3	6000	34							15	1		100	99	SPARE										100	100						
35										36							15	1		102	101	EXHAUST FAN: EF-1										102	102						
37	110	1	15				15	1	6000	38							15	1		104	103	HEAT RECOVERY VENTILATOR: HRV-3										104	104						
39	110	1	15				15	1	6000	40							15	1		106	105	PLUMBING FIXTURE: P-3										106	106						
41	400	1	15				40	3	6000	42							15	1		108	107	PLUMBING FIXTURE: P-4										108	108						
43	400	1	15				40	3	6000	44							15	1		110	109	PLUMBING FIXTURE: P-5										110	110						
45										46							15	1		112	111	PLUMBING FIXTURE: P-6a										112	112						
47							25	3	6000	48							15	1		114	113	WATER FOUNTAIN: P-10a										114	114						
49										50							15	1		116	115	LIGHTING										116	116						
51										52							15	1		118	117	LIGHTING										118	118						
53	1200	1	20				25	3	6000	54							15	1		120	119	LIGHTING										120	120						
55	1200	1	20				25	3	6000	56							15	1		122	121	LIGHTING										122	122						
57	600	1	15				15	1	1200	58							15	1		124	123	LIGHTING										124	124						
59	600	1	15				15	1	1200	60							15	1		126	125	LIGHTING										126	126						
61	400	1	15				15	1	600	62							15	1		128	127	RECEPTACLES: MEZZANINE										128	128						
63	1200	1	15				15	1	1050	64							15	1		130	129	LIGHTING: SPLASH PAD										130	130						
65	1200	1	15				15	1	1050	66							15	1		132	131	LIGHTING: SPLASH PAD										132	132						
										LOAD 'A'			LOAD 'B'			LOAD 'C'																							
										35,634			34,645			34,645																							

SUPPLY: 208V 3Ø 4W MAINS AMPACITY: 225 INCOMING: <input type="checkbox"/> BREAKER <input checked="" type="checkbox"/> LUGS MAIN BREAKER REQUIRED: <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO MAIN BREAKER AMPS: BUS MATERIAL: <input checked="" type="checkbox"/> COPPER <input type="checkbox"/> ALUMINUM BUS AND BREAKER RATING: 18kA										NAME PLATE: PANEL ' SP-2 '										LOCATION: CRAWLSPACE MOUNTING: <input checked="" type="checkbox"/> SURFACE <input type="checkbox"/> FLUSH MANUFACTURER: MODEL NO: BREAKER: <input type="checkbox"/> PLUG-IN <input checked="" type="checkbox"/> BOLT-ON SPD: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO SERVICE ENTRANCE RATED: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO																			
REV/CCT	VA	P	BKR	A	B	C	BKR	P	VA	CCT/REV	VA	P	BKR	A	B	C	BKR	P	VA	CCT/REV	VA	P	BKR	A	B	C	BKR	P	VA	CCT/REV	VA	P	BKR	A	B	C	BKR	P	VA
1	600	1	15				20	2	2300	2	600	1	15				20	2	2300	2	1	RECEPTACLES: OUTDOOR										2	2						
3	600	1	15				20	2	2300	4	600	1	15				20	2	2300	4	3	RECEPTACLES: OUTDOOR										4	4						
5	600	1	15				20	2	2300	6	600	1	15				20	2	2300	6	5	RECEPTACLES: OUTDOOR										6	6						
7	1200	1	20				20	2	2300	8	1200	1	20				20	2	2300	8	7	T-SLOT RECEPTACLES: SPLASH PAD, ROOM 119										8	8						
9	1200	1	20				20	2	2300	10	1200	1	20				20	2	2300	10	9	T-SLOT RECEPTACLES: ROOMS 124, 125										10	10						
11	1200	1	20				20	2	2300	12	1200	1	20				20	2	2300	12	11	T-SLOT RECEPTACLE: SUIT DRYER ROOM 115										12	12						
13	1200	1	20				20	2	2300	14	1200	1	20				20	2	2300	14	13	T-SLOT RECEPTACLE: SUIT DRYER ROOM 118										14	14						
15	1200	1	20				20	2	2300	16	1200	1	20				20	2	2300	16	15	T-SLOT RECEPTACLE: SUIT DRYER ROOM 110										16	16						
17	600	1	15				20	2	2300	18	600	1	15				20	2	2300	18	17	RECEPTACLES: ROOMS 113, 114, 122										18	18						
19	600	1	15				20	2	2300	20	600	1	15				20	2	2300	20	19	RECEPTACLES: ROOMS 116, 117										20	20						
21	1200	1	20				20	2	2300	22	1200	1	20				20	2	2300	22	21	T-SLOT RECEPTACLES: ROOMS 109, 102										22	22						
23	600	1	15				20	2	2300	24	600	1	15				20	2	2300	24	23	RECEPTACLES: ROOMS 112A, 112B										24	24						
25	1200	1	20				20	2	2300	26	1200	1	20				20	2	2300	26	25	RECEPTACLES: ROOM 120										26	26						
27	600	1	15				20	2	2300	28	600	1	15				20	2	2300	28	27	RECEPTACLE: DISHWASHER										28	28						
29	600	1	15				20	2	2300	30	600	1	15				20	2	2300	30	29	RECEPTACLE: FRIDGE										30	30						
31	600	1	15				20	2	2300	32	600	1	15				20	2	2300	32	31	RECEPTACLES: ROOM 120										32	32						
33	600	1	15				20	2	2300	34	600	1	15				20	2	2300	34	33	RECEPTACLES: ROOM 120										34	34						
35	600	1	15				15	1	1200	36	600	1	15				15	1	1200	36	35	RECEPTACLES: ROOM 104										36	36						
37	600	1	15				15	1	1200	38	600	1	15				15	1	1200	38	37	RECEPTACLES: ROOMS 103, 104										38	38						
39	600	1	15				15	1	1200	40	600	1	15				15	1	1200	40	39	RECEPTACLES: ROOM 103										40	40						
41	600	1	15				15	1	1200	42	600	1	15				15	1	1200	42	41	RECEPTACLES: ROOMS 105, 106										42	42						
43	1200	1	15				15	1	1200	44	1200	1	15				15	1	1200	44	43	VENDING MACHINE RECEPTACLE										44	44						
45	1200	1	15				15	1																															