



- NOTES:**
1. NEW STROBE TO BE MOUNTED ABOVE EXISTING GLAZING.
 2. PROVIDE A SECOND FIRE ALARM CABINET FOR ADDITIONAL POWER FOR NOTIFICATION DEVICES. CONTRACTOR TO CONFIRM FIRE ALARM EQUIPMENT WITH MANUFACTURER.
 3. PROVIDE AND INSTALL PLYWOOD BACKING WITHIN THE ELECTRICAL ROOM 200.
 4. THIS AREA HAS A NUMBER OF WALLS THAT ARE NOT SHOWN. CONTRACTOR TO COORDINATE ALL STROBE LOCATIONS ON SITE.

| Issue / rev. |
|--------------------------------------|
| 0 2016/07/15 ISSUED FOR CONSTRUCTION |
| # date issue notes |

professional seals



project information

SEVEN OAKS POOL
444 Adsum Drive
Winnipeg, MB
Canada

client

City of Winnipeg
4th Floor - 86 King Street
Winnipeg, MB

drawing information

ELECTRICAL MEZZANINE POWER & SYSTEMS - NEW
 drawn by: GCN
 approved by: [Signature]
 scale: AS NOTED
 date issued: 2016.07.15
 proj. #: 14-1736-008
 rev. #: R-0

SEVEN OAKS POOL RENOVATION & ADDITION
 BID OPPORTUNITY NO. 645-2016

MEZZANINE POWER/SYSTEMS PLAN - NEW
 SCALE: 1:100mm (24"x36")

File Name: P:\Projects\2014\14-1736-008\Draw\Elec\14-1736-008_E3-02.dwg - Tab: E3-02 Plotted By: dderochte 16/07/13 [Wed 3:41 pm]

This drawing must not be scaled. The contractor shall verify all dimensions and other data on site prior to commencement of work. All discrepancies, errors, and omissions are to be reported to the architect. Drawing and specifications are to be reported to the architect. No reproduction may be made without the permission of the architect, and when made, must bear his name. All rights to be returned to the architect on request.