

KEYNOTES:

- 1 REMOVE EXISTING CONDENSING UNIT AND RELOCATE TO ROOF IN NEW DESIGN. REMOVE EXISTING REFRIGERANT PIPING AND DISPOSE OF OFF SITE.
- 2 RETAIN EXISTING SUPPLY GRILLE AND ASSOCIATED DUCTWORK.
- 3 REMOVE EXISTING GRILLES AND DUCTWORK, PATCH OPENINGS IN CONCRETE AND MAKE GOOD.
- 4 REMOVE EXISTING GRILLES, RETAIN OPENING AND RE-USE FOR NEW SUPPLY GRILLE. CUT OR PATCH OPENINGS TO SUIT NEW SUPPLY GRILLES. REFER TO M1-02 FOR ASSOCIATED DUCTWORK DEMOLITION.
- 5 REMOVE EXISTING CABINET UNIT HEATER AND DISPOSE OF OFF SITE.
- 6 EXISTING PLUMBING FIXTURES TO BE REMOVED AND DISPOSED OF OFF SITE. CAP PLUMBING LINES IN BASEMENT BELOW.
- 7 REMOVE EXISTING WALL A/C UNIT AND DISPOSE OF OFF SITE. PATCH HOLE IN WALL AND MAKE GOOD.

issue / rev.

issue / rev.	date	issue notes
0	2016/07/15	ISSUED FOR CONSTRUCTIONS

professional seals



project information

SEVEN OAKS POOL

444 Adsum Drive
Winnipeg, MB
Canada

client

City of Winnipeg
4th Floor - 86 King Street
Winnipeg, MB

drawing information

MECHANICAL MAIN FLOOR PLAN PLUMBING AND HVAC - DEMO

drawn by: RLR

approved by: *[Signature]*

scale: AS NOTED


date issued: 2016.07.15

proj. #: 14-1736-008

rev. #: R-0


SEVEN OAKS POOL RENOVATION & ADDITION

BID OPPORTUNITY NO. 645-2016



1 MAIN FLOOR PLAN - PLUMBING AND HVAC DEMO
SCALE: 1:100

SCALE VERIFIED BY: *[Signature]*



File Name: P:\Projects\2014\14-1736-008\Mech\14-1736-008_M1-01.dwg - Tab: M1-01 Plotted By: dderoché 16/07/13 [Wed 3:53pm]

This drawing must not be scaled. The contractor shall verify all dimensions and other data on site prior to commencement of work. All discrepancies, errors, and omissions are to be reported to the architect. Drawing and specifications, as instruments of service, are the property of the architect. The copyright in this same being reserved to him. No reproduction may be made without the permission of the architect, and when made, must bear his name. All prints to be returned to the architect on request.