

**KEYNOTES:**

- 1 RETAIN EXISTING EXHAUST DUCT TO TIE INTO NEW EXHAUST SYSTEM.
- 2 REMOVE EXISTING DUCT. RETAIN PENETRATIONS FOR NEW DUCTWORK AND GRILLES.
- 3 RETAIN EXISTING DUCT SERVING MEZZANINE OFFICE. MODIFY DUCT TO SUIT NEW DESIGN.
- 4 RETAIN WASHROOM AND CHLORINE EXHAUST SYSTEM.
- 5 RETAIN EXISTING POOL EXHAUST SYSTEM.
- 6 REMOVE EXHAUST FAN F-4 AND ASSOCIATED DUCTWORK TO EXTENT SHOWN.
- 7 REMOVE SUPPLY DUCT TO EXTENT SHOWN AND CAP SUPPLY DUCT AT FLOOR LEVEL.
- 8 REMOVE EXISTING AIR HANDLER AND ASSOCIATED DUCTWORK, CONTROLS, AND EQUIPMENT.
- 9 REMOVE EXISTING WALL A/C UNIT AND DISPOSE OF OFF SITE. PATCH HOLE IN WALL.
- 10 RETAIN EXISTING WATER HEATER AND MOP SINK (NOT SHOWN FOR CLARITY).
- 11 REMOVE EXISTING ELECTRIC HEATING COIL AND DISPOSE OF OFF SITE. REMOVE ALL RELATED POWER AND CONTROLS.

**issue / rev.**

#	date	issue notes
0	2016/07/15	ISSUED FOR CONSTRUCTION

**professional seals**



**project information**

**SEVEN OAKS POOL**

444 Adsum Drive  
Winnipeg, MB  
Canada

**client**

City of Winnipeg  
4th Floor - 86 King Street  
Winnipeg, MB

**drawing information**

**MECHANICAL MEZZANINE FLOOR PLAN HVAC - DEMO**

drawn by: RLR

approved by: *[Signature]*

scale: AS NOTED

date issued: 2016.07.15

proj. #: 14-1736-008


rev. #: R-0

**SEVEN OAKS POOL RENOVATION & ADDITION**

BID OPPORTUNITY NO. 645-2016

1 MEZZANINE PLAN - HVAC DEMO  
SCALE: 1:100

SCALE VERIFIED BY: *[Signature]*



This drawing must not be scaled. The contractor shall verify all dimensions and other data on site prior to commencement of work. All discrepancies, errors, and omissions are to be reported to the architect. Drawing and specifications, as instruments of service, are the property of the architect, and when made, must bear his name. No reproduction may be made without the permission of the architect, and when made, must bear his name. All prints to be returned to the architect on request.

File Name: P:\Projects\2014\14-1736-008\14-1736-008\_M1-02.dwg - Tab: M1-02 Plotted By: aderoche 16/07/13 [Wed 3:53pm]