



768-2016 ADDENDUM 2

ST VITAL LIBRARY INTERIOR RENOVATION 6 FERMOR AVE

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: December 2, 2016
BY: Taylor Hammond
BridgmanCollaborative Architecture
TELEPHONE NO. (204) 488-3857 ext. 23

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20131129

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

SECTION 01 51 00 – TEMPORARY UTILITIES

Delete: Specification section in its entirety

SECTION 06 16 43 – GYPSUM SHEATHING

Add: 2.2.1.14.2 13mm (1/2") CGC Securock Glass Mat Sheathing

Add: 2.2.2.14.2 16mm (5/8") CGC Securock Glass Mat Sheathing, Type X

SECTION 07 21 13 – BOARD INSULATION

Revise: 2.1.1.2 to read: Compressive strength: to ASTM D1621, minimum **15** Psi

SECTION 07 27 00 – AIR BARRIERS

Add: 2.1.1 approved alternate: Sopraseal Stick 1100T/ Sopraseal Stick 1100T Winter by Soprema

Add: 2.1.2 approved alternate: Sopraseal WFM by Soprema

Add: 2.1.3 approved alternate: Sopramastic SP2 by Soprema

Add: 2.1.4 approved alternate: Sopraseal Stick Primer by Soprema

Add: 2.1.5 approved alternate: Sopramastic SP2 by Soprema

Add: 2.1.6 approved alternate: Sopraseal LM 200T by Soprema

Add: 2.1.7 approved alternate: Sopramastic SP2 by Soprema
Add: 2.2.1 approved alternate: Sopraseal Stick VP by Soprema
Add: 2.2.2 approved alternate: Sopraseal Stick 1100T/ Sopraseal Stick 1100T Winter by Soprema
Add: 2.2.3 approved alternate: Sopraseal Stick VP by Soprema
Add: 2.2.4 approved alternate: Sopraseal WFM by Soprema
Add: 2.2.7 approved alternate: Sopramastic SP2 by Soprema

SECTION 07 52 00 – MODIFIED BITUMINOUS MEMBRANE ROOFING

Delete: 2.1 DECK COVERING

SECTION 08 42 29.23 – SLIDING AUTOMATIC ENTRANCES

Add: 2.1.2 NABCO Canada, 1450 Meyerside Dr., Suite 402, Mississauga, ON L5T 2N5 Phone: (289) 904-0273 Fax: (855) 631-0742
Add: 2.1.3 Horton Automatics, 4242 Baldwin Blvd, Corpus Christi, TX 78405 Toll Free: (800) 531-3111 Phone: (361) 888-5591
Add: 2.2.3 Model: Nabco/Gyrotech Model GT1175 Whisperslide Automatic Sliding Door
Add: 2.2.4 Model: Horton Automatics Proslide Series 2003 Belt Drive with Aluminum Door Panels

SECTION 08 71 00 – DOOR HARDWARE

Add: 3.9.1 Auto Operator approved alternates: Nabco/Gyrotech Model GT710 standard duty automatic door operator and Horton Automatics Series 7100 Swing Door Operator

DRAWINGS

Replace: 768-2016_Drawing_A101-R1 with 768-2016_Addendum_2_Drawing_A101-R2

QUESTIONS & ANSWERS

Is carpet padding required at stair locations?

Carpeting is to be installed as per manufacturer's directions. Carpeting can be applied directly to stairs without padding when indicated by manufacturer.