



ALARM DISPLAY & SWITCH/BUTTON QUICK REFERANCE



GREEN NORMAL MODE LT01	RED WATER OVERFLOW LT02 - 10002	RED SLUICE GATE ALARM LT03 - 10014	RED 120 VAC POWER FAIL LT04 - 10008	RED UPS ALARM / BATT MODE LT05 - 10009	GREEN P1 RUN LT06 - 10026	P2 RUN LT07 - 10034	GATE OPEN LT08 - 10005	RED WIRELESS FAIL LT09 - 10015	RED PUMP AUTO INHIBITED LT10 - 10019
AMBER TEST MODE LT11 - 10001	RED GATE HIGH LEVEL LT12 - 10003	RED GATE NOT IN REMOTE LT13 - 10004	600 VAC PWR FAIL LT14 - 10006	AMBER UPS CHARGING LT15 - 10010	RED P1 FAIL LT16 - 10028	P2 FAIL LT16 - 10036	GATE CLOSED LT18 - 10006	LT19 -	RED PUMP LOW LEVEL DISABLE LT20 - 10013

DOOR ALARM DISPLAY LIGHT

C:\Users\j2016\OneDrive\Autodesk\WSP\working_drawing\sheet\sheet1-15page_19.dwg - tab1.E-1
 Sep 13, 2016 - 4:10pm
 C:\Users\j2016\OneDrive\Autodesk\WSP\working_drawing\sheet\sheet1-15page_19.dwg - tab1.E-1

NOTE:
These design documents are prepared solely for the use by the party with whom the design professional has entered into a contract and there are no representations of any kind made by the design professional to any party with whom the design professional has not entered into a contract.

METRIC
WHOLE NUMBERS INDICATE MILLIMETRES
DECIMALIZED NUMBERS INDICATE METRES



G.S.M. ELEV.					
1600 BUFFALO PLACE, WINNIPEG, MANITOBA CANADA R3T 6B8 PHONE: 204-477-6650 FAX: 204-474-2864 WWW.WSPGROUP.COM		DESIGNED BY: DG	CHECKED BY: HP	BID OPPORTUNITY: 789-2016 PLOT DATE: 2016/09/07	
DRAWN BY: DG	APPROVED BY: HP	HOR. SCALE: AS NOTED VERTICAL: AS NOTED		RELEASED FOR CONSTRUCTION	
NO. 1	ISSUED FOR TENDER	DATE: 09/07/16	BY: HP	DATE: 2016/09/07	DATE:

THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT

OUTFALL GATE CHAMBER UPGRADES
 RUBY STREET
 SRS OUTFALL GATE CHAMBER

RTU-01 PANEL DOOR
 ALARM DISPLAY LIGHT

CONSULTANT DRAWING NUMBER: 5516047 - 115
 SHEET 31 OF 34
 CITY DRAWING NUMBER: LD-7952