



- CONSTRUCTION NOTES:**
- EXISTING VALVES & PIPING DO NOT HAVE DISASSEMBLY POINTS. EXISTING VALVES MUST BE CUT APART TO FACILITATE VALVE REPLACEMENT.
 - CONTRACTOR TO EXERCISE EXTREME CARE WHEN REMOVING THE EXISTING VALVES & TAKE ALL NECESSARY PRECAUTIONS TO NOT DAMAGE THE EXISTING PIPING & FITTINGS.

METRIC
WHOLE NUMBERS INDICATE MILLIMETRES
DECIMALIZED NUMBERS INDICATE METRES



BID OPPORTUNITY NO. 805-2016

LOCATION APPROVED UNDERGROUND STRUCTURES				
SUPR. U/G STRUCTURES COMMITTEE	DATE			
NOTE: LOCATION OF UNDERGROUND STRUCTURES AS SHOWN ARE BASED ON THE BEST INFORMATION AVAILABLE. BUT NO GUARANTEE IS GIVEN THAT ALL EXISTING UTILITIES ARE SHOWN OR THAT THE GIVEN LOCATIONS ARE EXACT. CONFIRMATION OF EXISTENCE AND EXACT LOCATION OF ALL SERVICES MUST BE OBTAINED FROM THE INDIVIDUAL UTILITIES BEFORE PROCEEDING WITH CONSTRUCTION.				
0	ISSUED FOR CONSTRUCTION	16/10/13	KLC	
	NO. REVISIONS	YYMMDD	BY	DATE

DESIGNED BY: ADB
DRAWN BY: ADL
HOR SCALE: AS NOTED
VERT. SCALE: N/A

CHECKED BY: [Signature]
APPROVED BY: [Signature]
RELEASED FOR CONSTRUCTION: [Signature]
DATE: Oct 13/2016

PROFESSIONAL'S SEAL
PROVINCE OF MANITOBA
B. BRAUN
Member
REG. PROF. MEMBER
CONSULTANT DRAWING NO.
60506849-SHT-30-0000-C-3001

THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT

BRANCH I AQUEDUCT
EAST TUNNEL SHAFT UPGRADES

EXISTING CHAMBER & PIPING
PLANS, SECTIONS & REMOVALS

SHEET 3 OF 8
CITY DRAWING NUMBER
1-0751A-C0002-001
REV 0