

PLC RACK – LAYOUT

BMX CPS 2010 POWER SUPPLY 24 VDC	BMX P58 1020 PROCESSOR	BMX DAI 1604 120 VAC INPUT 16 CHANNEL	BMX DRA 1605 120 VAC RELAY OUTPUT 16 CHANNEL	BMX AMI 0410 ANALOG INPUT 4 CHANNEL FULLY ISOLATED	BMX AMI 0410 ANALOG INPUT 4 CHANNEL FULLY ISOLATED	BMX AMO 0410 ANALOG OUTPUT 4 CHANNEL FULLY ISOLATED	BMX MEM 010 SLOT COVER
SLOT 0	SLOT 1	SLOT 2	SLOT 3	SLOT 4	SLOT 5	SLOT 6	SLOT 7



DESIGNED BY BLM	
DRAWN BY SCK	
CHECKED BY -	
APPROVED BY -	
HOR. SCALE	
VERTICAL	
0	Issued for Tender 16/10/27 BLM
NO.	REVISIONS DATE BY DATE

RELEASED FOR CONSTRUCTION

CONSULTANT PROJECT NO. 163526

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT

NORTH END SEWAGE TREATMENT PLANT
NEWPCC MAIN BUILDING - HVAC REPLACEMENT

PLC RACK - LAYOUT

CITY DRAWING NUMBER 1-0101M-E0060-001
SHEET 9 OF 21

E-03