



105-2017 ADDENDUM 1

ESPLANADE RIEL PEDESTRIAN BRIDGE 2017 MAINTENANCE WORKS

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: February 23, 2017
BY: Mohamed Mady, Ph.D., P.Eng.
TELEPHONE NO. 204 986-4046

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph ^ of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: E7.5.2(b) to read: Pressure wash existing concrete surfaces to be repainted to remove existing paint. All peeled paint, flakes and debris shall be collected; however water does not need to be contained.