



## 253-2017 ADDENDUM 1

### REPAIR OF SODIUM HYPOCHLORITE STORAGE TANK TK-J540A

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: March 21, 2017  
BY: Dave Carr  
TELEPHONE NO. 204 986-2091

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20160708

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.**

---

#### **PART E – SPECIFICATIONS**

Revise: E1.2 (b) to read:

**Re-line the tank interior with a new corrosion barrier. Abrasive blast the tank interior surface using a non-silicon based abrasive (eg. Garnet) to remove affected barrier to substrate; apply two (2) layers of 1.5 oz. boron-free glass; apply two (2) layers of synthetic veil, using a high quality epoxy vinyl ester resin (Reichhold Dion 9102, Derakane-D411, AOC-Vipel F010-CN, AOC-Vipel K022-ACA) incorporating a BPO/DMA cure system; post cure with dry heat in accordance with the resin manufacturer's recommendation; apply a resin rich flood coat complete with an air dry additive to the liner surface.**

Revise: E1.3 to read:

The Contractor shall operate in accordance with the requirement hereinafter specified.

**(a) Specification Title:**

- (i) Sodium Hypochlorite Tank TK-J540A Inspection Report APPENDIX C**
- (ii) Sodium Hypochlorite Tank TK-J540A Inspection Report (photos) APPENDIX A**
- (iii) Sodium Hypochlorite Tank TK-J540A Inspection Report (photos) APPENDIX B**

Add: **APPENDIX C**