

AL EQUIPMENT SCHEDULE	
FIXTURE	SPECIFICATION
HEAT RECOVERY VENTILATOR	LIFEBREATH 95 MAX, SET TO 50 CFM, OR APPROVED EQUAL IN ACCORDANCE WITH B7. INCLUDING CONCENTRIC/ DUAL HOOD; #99-190 (5")
INLINE DUCT HEATER	THERMOLEC STANDARD FRESH-AIR & ZONE HEATER, #TER-5- 1120 (1KW), OR APPROVED EQUAL IN ACCORDANCE WITH B7.
SUPPLY GRILLE	E.H. PRICE DOUBLE DEFLECTION SUPPLY GRILLE C/W STEEL DAMPER, #520D-F-SDF-L-A-B12, 254mm x 150mm. OR APPROVED EQUAL IN ACCORDANCE WITH B7.
RETURN GRILLE	#520 E.H. PRICE FIXED LOUVER, 45°- F-L-A-B12, 254mm x 150mm, C/W DUCT ADAPTER TO CONNECT TO RETURN DUCT. OR APPROVED EQUAL IN ACCORDANCE WITH B7.
EXHAUST FAN	GREENHECK EXHAUST FAN #SE1-12-432-VG, DISCHARGE HOOD C/W BIRDSCREEN, INLET SAFETY SCREEN & BDD. OR APPROVED EQUAL IN ACCORDANCE WITH B7.
INTAKE LOUVER	750x500 O/A INTAKE LOUVER C/W BIRD SCREEN. LOUVER TO BE EH PRICE ZE445. INTAKE C/W UPTURNED ELBOW OPEN ENDED AT HIGH LEVEL (OR APPROVED EQUAL IN ACCORDANCE WITH B7
	FIXTURE HEAT RECOVERY VENTILATOR INLINE DUCT HEATER SUPPLY GRILLE RETURN GRILLE EXHAUST FAN

1. PROVIDE A SUPPLY & RETURN BALANCE DAMPER IF NOT INTEGRATED WITHIN THE HRV UNIT. 2. COLOUR OF LOUVERS TO BE CONFIRMED BY ARCHITECT

CONTRACTOR TO COORDINATE ALL CONTROLS FOR HEATING & COOLING.

Issue/Revision Date Sheet No:

Addendum No.2 17 06 28 17 06 08 ISSUED FOR CONSTRUCTION

M102r1

This drawing is property of the Architect and cannot be reproduced or used without the consent of the Architect. The contractor is responsible for checking and verifying all levels and dimensions and shall report all discrepancies to the Architect and obtain chaffication prior the compresent work clarification prior to commencing work.