



MECHANICAL EQUIPMENT SCHEDULE		
LABEL	FIXTURE	SPECIFICATION
HRV-1	HEAT RECOVERY VENTILATOR	LIFEBREATH 95 MAX, SET TO 50 CFM, OR APPROVED EQUAL IN ACCORDANCE WITH B7.
DH-1	INLINE DUCT HEATER	THERMOLEC STANDARD FRESH-AIR & ZONE HEATER, #TER-5-1120 (1KW), OR APPROVED EQUAL IN ACCORDANCE WITH B7.
S-1	SUPPLY GRILLE	E.H. PRICE DOUBLE DEFLECTION SUPPLY GRILLE C/W STEEL DAMPER, #520D-F-SDF-L-A-B12, 254mm x 150mm. OR APPROVED EQUAL IN ACCORDANCE WITH B7.
R-1	RETURN GRILLE	E.H. PRICE FIXED LOUVER, 45°- F-L-A-B12, 254mm x 150mm, C/W DUCT ADAPTER TO CONNECT TO RETURN DUCT. OR APPROVED EQUAL IN ACCORDANCE WITH B7.
EF-1	EXHAUST FAN	GREENHECK EXHAUST FAN #SE1-12-432-VG, DISCHARGE HOOD C/W BIRDSCREEN, INLET SAFETY SCREEN & BDD. OR APPROVED EQUAL IN ACCORDANCE WITH B7.
F/A-1	INTAKE LOUVER	EH PRICE INTAKE LOUVER #ZE445.750X500 C/W BIRD SCREEN, & UP-TURNED ELBOW OPEN ENDED AT HIGH LEVEL C/W BIRD SCREEN. OR APPROVED EQUAL IN ACCORDANCE WITH B7.

**GENERAL NOTES:**

1. PROVIDE A SUPPLY & RETURN BALANCE DAMPER IF NOT INTEGRATED WITHIN THE HRV UNIT.

1 MECHANICAL HVAC PLAN  
1 : 50