



NOTES:

1. PROVIDE ALTERNATE PRICE TO PROVIDE DMX CONTROLS AND ASSOCIATED WEATHERPROOF ENCLOSURE. PHOTOCELL AND POTENTIOMETER CONTROL FOR DMX CONTROLLED LIGHTING NOT REQUIRED IN ALTERNATE PRICE. REFER TO DRAWING E4.0.
2. UTILIZE L.B. FITTINGS FOR 90-DEGREE BENDS C/W WEATHERPROOF COUPLING.
3. TRANSITION TO EMT CONDUIT ABOVE GRADE.
4. PROVIDE DC POTENTIOMETER OR RESISTOR ON 0-10V CONTROL WIRES WITHIN JB TO SET DIMMING LEVEL. CONFIRM DIMMING LEVEL WITH CITY OF WINNIPEG AT TIME OF INSTALLATION.

1 1919 MARQUEE NORTH ELEVATION - ELECTRICAL LAYOUT
 E3.1 SCALE: N.T.S.

10331-05
MCW
MCW / AGE
 Consulting Professional Engineers

Note: This drawing includes contextual information provided by HTFC Planning & Design: Landscaped Design of Lily st. including existing curb, building, Hydro duct and lights (5515038-Base Plan (Lily Street).dwg 5515038-Existing Utilities.dwg)



ISSUED FOR CONSTRUCTION 2017/02/03	
1602	2016/10/20

MONTEYNE
 architecture works
 INCORPORATED

1919 MARQUEE
 Winnipeg, Manitoba
 INTERSECTION OF LILY ST. & MARKET AVE.
 ELEVATIONS -
 ELECTRICAL

APEGM
 Certificate of Authorization
MCW/AGE Consulting Professional Engineers
 No. 589 Expiry: April 30, 2017

THIS IS A PRINT OF A DOCUMENT THAT HAS BEEN ELECTRONICALLY AUTHENTICATED WITH TECHNOLOGY AUTHORIZED BY THE APEGM. THE ORIGINAL IS IN ELECTRONIC FORM.

E3.1