



381-2017 ADDENDUM 2

PAINTING OF POOL TANK CONCRETE SURFACES & RELATED WORKS AT WESTDALE OUTDOOR POOL – 550 DALE BOULEVARD

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: May 1, 2017
BY: Lou Chubenko
TELEPHONE NO. 204 986-2727

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20160708

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

Revise: D2.2(g) to read: Apply two (2) coats of specified rubber based swimming pool paint for floor/walls and one (1) coat for pool marking.

PART E – SPECIFICATIONS

Revise: E5.1 to read: Painting to be by professional applicator with acceptable experience of 3-years in using rubber based swimming pool paints.

Revise: E5.3 to read: Acceptable Product: INSUL-X Rubber-Based swimming pool paint RP -2700, as manufactured by Benjamin Moore & Co.