



## 39-2017 ADDENDUM No. 3

### 4R WINNIPEG DEPOT – EAST WINNIPEG COMMUNITY RESOURCE RECOVERY CENTRE

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: April 28, 2017  
BY: Phillip Pawluk, C.E.T., P.Eng.  
TELEPHONE NO. 204 896-1209

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20160708

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph ^ of Form A: Bid may render your Bid non-responsive.**

---

#### **PART A – BID SUBMISSION**

Replace: 39-2017 \_Bid\_Submission with 39-2017 \_Addendum\_3\_Bid\_Submission. The following is a summary of changes incorporated in the replacement Bid Submission:

Form B (R3):           Revise quantity of item A.31 (i)

                              Revise quantity of item B.1 (ii)

Page numbering on some forms may be changed as a result.

#### **PART B – BIDDING PROCEDURES**

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, May 3, 2017.

#### **PART E – SPECIFICATIONS**

##### **E20. STRUCTURAL CONCRETE**

Delete:            Clause 20.7.5 (c)  
                          Air-void system testing is not required.

Delete:            Clause 20.7.5 (d)  
                          Rapid chloride permeability testing is not required.

##### **DIVISION 12:**

###### **Section 12 24 13 – Roller Shades**

Add Clause 2.1.1.1 – Approved Manufacturer – Altex Deko LL S-70 Roller or approved equivalent in accordance with B7.

##### **DIVISION 23:**

###### **Section 23 73 11 – Air Handling Units - Packaged**

Add Clause 2.1.6 – Approved Manufacturer – LG or approved equivalent in accordance with B7

## **DRAWINGS**

Replace: 39-2017\_Drawing\_C04\_Sht05-R0 with 39-2017\_Addendum\_3\_Drawing\_C04\_Sht05-R1

Replace: 39-2017\_Drawing\_B01\_Sht09-R0 with 39-2017\_Addendum\_3\_Drawing\_B01\_Sht09-R1

Replace: 39-2017\_Drawing\_S03\_Sht19-R0 with 39-2017\_Addendum\_3\_Drawing\_S03\_Sht19-R1

Replace: 39-2017\_Drawing\_S04\_Sht20-R0 with 39-2017\_Addendum\_3\_Drawing\_S04\_Sht20-R1

Replace: 39-2017\_Drawing\_S05\_Sht21-R0 with 39-2017\_Addendum\_3\_Drawing\_S05\_Sht21-R1

Replace: 39-2017\_Drawing\_L01\_Sht41-R0 with 39-2017\_Addendum\_3\_Drawing\_L01\_Sht41-R1

## **QUESTIONS AND ANSWERS**

Q1 Are form-liners required for the retaining wall?

A1 Yes. Form-liner is required as per Clause 20.4.14, Clause 20.6.5, and Clause 20.6.13(b)(i).

Q2 Is damp-proofing required on the retaining wall?

A2 Yes. Damp Proofing is required as per Clause 20.4.28 & Clause 20.6.13(d)(ii).