



NOTES:

1. CONFIGURE FLOW METER, FIT-008 FOR 4-20mA PASSIVE OUTPUT.

File Name: c:\project\wise\working directory\active\408\k\404625\43175009-13 chevrier-loops.dwg

NO.	REVISION	DATE	BY
0	ISSUED FOR BID OP 634-2017	17/11/23	B.L.M.


DILLON CONSULTING

Winnipeg
 WATER AND WASTE DEPARTMENT
 ENGINEERING DIVISION

DATE: 17/07/06 PROJECT No. 175009

THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT
 ENGINEERING DIVISION

DESIGNED BY	CHECKED BY
B.L.M.	B.L.M.
DRAWN BY	APPROVED BY
S.C.K.	

2017 REHABILITATION OF PUBLIC WATER SERVICE
 OUTLETS: PAVEMENT WORKS, BUILDING SUPPLY
 AND REPAIRS, DEMOLITION AND ELECTRICAL
CHEVRIER BOULEVARD
0801-FIT-008 LOOP DIAGRAM

SHEET 22 OF 33
CITY DRAWING NUMBER
D-14928