



FUSE SCHEDULE			
TB	IDENTIFIER	SIZE	RATED CURRENT (A) FA
TB01	1P	5x20mm	0.1
	2P	5x20mm	0.1
	3P	5x20mm	0.1
	4P	5x20mm	0.1
	5P	5x20mm	0.1
	6P	5x20mm	0.1
	7P	5x20mm	0.1
	8P	5x20mm	0.1
	9P	5x20mm	0.1
	10P	5x20mm	0.1
	11P	5x20mm	0.1
	12P	5x20mm	0.1
	13P	5x20mm	0.1
	14P	5x20mm	0.1
	15P	5x20mm	0.1
	16P	5x20mm	0.1
	17P	5x20mm	0.1
	18P	5x20mm	0.1
	19P	5x20mm	0.1
	20P	5x20mm	0.1
	21P	5x20mm	0.1
	22P	5x20mm	0.1
	23P	5x20mm	0.1
	24P	5x20mm	0.1
	25P	5x20mm	0.1
	26P	5x20mm	0.1
	27P	5x20mm	0.1
	28P	5x20mm	0.1
	29P	5x20mm	0.1
	30P	5x20mm	0.1
	31P	5x20mm	0.1
	32P	5x20mm	0.1

- NOTES**
- ALL 120VAC POWER WIRING TO BE A MINIMUM OF 12 AWG UNLESS OTHERWISE INDICATED.
  - ALL 24VDC POWER WIRING TO BE A MINIMUM OF 14 AWG UNLESS OTHERWISE INDICATED.



NO.	REVISIONS	DATE	DESIGN	CHECK
00	ISSUED FOR TENDER, BID OPP. 639-2017	2017-07-25	TMC	BJC

**SNC-LAVALIN INC.**  
 148 Nature Park Way  
 Winnipeg, MB, Canada R3P 0X7  
 204-786-8080

DESIGNED BY: T. CHURCH  
 DRAWN BY: Y. KONIG  
 SCALE: NTS  
 DATE: 2017/05/18  
 CONSULTANT NO.:

CHECKED BY: B. CLEVEN  
 APPROVED BY: B. CLEVEN  
 ISSUED FOR CONSTRUCTION BY:  
 DATE:

ENGINEER'S SEAL

**PRELIMINARY**  
 NOT TO BE  
 USED FOR  
 CONSTRUCTION

**THE CITY OF WINNIPEG**  
 WATER AND WASTE DEPARTMENT

COMMUNITY ROW WASTEWATER PUMPING STATION  
 2017 UPGRADES  
 IO WIRING DIAGRAMS  
 CONTROL PANEL CP-L81  
 DISCRETE INPUTS

CITY DRAWING NUMBER: 1-0130L-A0003  
 SHEET: 001  
 REV: 00  
 SIZE: A1