



FUSE SCHEDULE			
TB	IDENTIFIER	SIZE	RATED CURRENT (A) FA
TB02	33P	5x20mm	0.1
	34P	5x20mm	0.1
	35P	5x20mm	0.1
	36P	5x20mm	0.1
	37P	5x20mm	0.1
	38P	5x20mm	0.1
	39P	5x20mm	0.1
	40P	5x20mm	0.1
	41P	5x20mm	0.1
	42P	5x20mm	0.1
	43P	5x20mm	0.1
	44P	5x20mm	0.1
	45P	5x20mm	0.1
	46P	5x20mm	0.1
	47P	5x20mm	0.1
	48P	5x20mm	0.1
	49P	5x20mm	0.1
	50P	5x20mm	0.1
	51P	5x20mm	0.1
	52P	5x20mm	0.1
	53P	5x20mm	0.1
	54P	5x20mm	0.1
	55P	5x20mm	0.1
	56P	5x20mm	0.1
57P	5x20mm	0.1	
58P	5x20mm	0.1	
59P	5x20mm	0.1	
60P	5x20mm	0.1	
61P	5x20mm	0.1	
62P	5x20mm	0.1	
63P	5x20mm	0.1	
64P	5x20mm	0.1	

- NOTES**
- ALL 120VAC POWER WIRING TO BE A MINIMUM OF 12 AWG UNLESS OTHERWISE INDICATED.
  - ALL 24VDC POWER WIRING TO BE A MINIMUM OF 14 AWG UNLESS OTHERWISE INDICATED.



NO.	REVISIONS	DATE	DESIGN	CHECK
00	ISSUED FOR TENDER, BID OPP. 639-2017	2017-07-25	TMC	BJC

**SNC-LAVALIN INC.**  
 148 Nature Park Way  
 Winnipeg, MB, Canada R3P 0X7  
 204-786-8080

DESIGNED BY: T. CHURCH  
 DRAWN BY: Y. KONIG  
 SCALE: NTS  
 DATE: 2017/05/18  
 CONSULTANT NO.:

CHECKED BY: B. CLEVEN  
 APPROVED BY: B. CLEVEN  
 ISSUED FOR CONSTRUCTION BY:  
 DATE:

ENGINEER'S SEAL

**PRELIMINARY**  
 NOT TO BE  
 USED FOR  
 CONSTRUCTION

**THE CITY OF WINNIPEG**  
 WATER AND WASTE DEPARTMENT

COMMUNITY ROW WASTEWATER PUMPING STATION  
 2017 UPGRADES  
 10 WIRING DIAGRAMS  
 CONTROL PANEL CP-L81  
 DISCRETE INPUTS

CITY DRAWING NUMBER: 1-0130L-A0003  
 SHEET: 002  
 REV: 00  
 SIZE: A1

DRAWING NUMBER	REFERENCE DRAWINGS