


1 MAIN FLOOR PLAN - STORAGE TRACKS REBALANCING - VENTILATION
SCALE: 1/32" = 1'-0"



KEY PLAN
NTS

GENERAL NOTES


- A. ALL ABANDONED EQUIPMENT AND SERVICES WITHIN AREA OF WORK SHALL BE REMOVED.
- B. THIS BUILDING MAY CONTAIN ASBESTOS. REFER TO FRONT END SPECIFICATIONS FOR FURTHER INFORMATION.

KEY NOTES

1. BALANCE THE EXISTING TRANSFER FAN, F-2 TO 26,040 CFM. FAN MAY BE BALANCED USING THE EXISTING VFD OR THROUGH THE PULLEYS AND BELTS.
2. BALANCE THE EXISTING TRANSFER AIR OUTLETS TO THE FLOWS INDICATED.
3. BALANCE THE EXISTING EXHAUST FAN, EF-08 TO 4,749 CFM.
4. BALANCE THE EXISTING EXHAUST FAN, EF-03 TO 4,798 CFM.
5. REFER TO SPECIFICATION FOR SEQUENCE MODIFICATION TO EF-2.

5			
4			
3			
2			
1			
0	ISSUED FOR CONSTRUCTION	JH	21/08/17
NO.	Description	BY	DD/MM/YY

ENGINEERS
GEOSCIENTISTS
MANITOBA
Certificate of Authorization
SMS Engineering Ltd.
No. 166



770 Bradford Street
Winnipeg, Canada
T 204 775-0291
SMSeng.com



Winnipeg Transit

Project Title
CITY OF WINNIPEG FORT ROUGE
TRANSIT BASE - STORAGE TRACK
1-12 VENTILATION UPGRADE
WINNIPEG MANITOBA

Drawing Title
MAIN FLOOR PLAN - STORAGE
TRACKS REBALANCING -
VENTILATION

Drawn By GB	Checked By XZ	Approved By JH
Scale AS SHOWN	Date AUGUST 2017	Project No. 16-149-02
Revision Number 0	Drawing Number M4.2	Sheet Order 7 OF 9