



EXISTING SAMPLE COMPONENTS

- ① PIPE, 500#
- ② SLIP-ON FLANGE, 150#, 500#
- ③ GROOVED COUPLING, 500#
- ④ PIPE, 50#
- ⑤ BALL VALVE, 50#

THIS ISOMETRIC SHOWS SAMPLE 4 EXISTING PIPING.
 SAMPLES 2 AND 6 HAVE SIMILAR ARRANGEMENT.
 SAMPLES 1, 3 AND 5 HAVE SIMILAR BUT "OPPOSITE HAND" ARRANGEMENT.
 EXACT DIMENSIONS MAY DIFFER BETWEEN SAMPLES 1-6.

NOTES:

1. PROVIDE TEMPORARY SUPPORTS AT POINTS OF SAMPLE DISCONNECTION TO PREVENT STRAIN ON EXISTING PIPING DURING SAMPLE REMOVAL AND REPLACEMENT.
2. DIMENSIONS SHOWN ARE APPROXIMATE. FIELD CONFIRM ALL DIMENSIONS AND EXISTING CONDITIONS.
3. LINEAL DIMENSIONS AND NOMINAL PIPE SIZES SHOWN IN MILLIMETERS, ELEVATIONS SHOWN IN METERS FROM LOCAL FLOOR LEVEL.

A	17/11/30	ISSUED FOR INFORMATION	-	-
NO.	YY/MM/DD	DESCRIPTION	DESIGN BY	DESIGN CHECK
REVISIONS / ISSUE				
NEWPCC RAS PIPE ASSESSMENT PILOT INSPECTION PROGRAM				
SAMPLES 1 TO 6 - TYPICAL PIPING ISOMETRIC				
16-0107-023		ISO-001	REV: A	