



EXISTING SAMPLE COMPONENTS

- ① PIPE, 300#
- ② 90 ELBOW, LR, 300#, WITH HANGER ATTACHMENT LUG
- ③ SLIP-ON FLANGE, 150#, 300#

NOTES:

1. PROVIDE TEMPORARY SUPPORTS AT POINTS OF SAMPLE DISCONNECTION TO PREVENT STRAIN ON EXISTING PIPING DURING SAMPLE REMOVAL AND REPLACEMENT.
2. DIMENSIONS SHOWN ARE APPROXIMATE. FIELD CONFIRM ALL DIMENSIONS AND EXISTING CONDITIONS.
3. LINEAL DIMENSIONS AND NOMINAL PIPE SIZES SHOWN IN MILLIMETERS, ELEVATIONS SHOWN IN METERS FROM LOCAL FLOOR LEVEL.

A	17/11/30	ISSUED FOR INFORMATION	-	-
NO.	YY/MM/DD	DESCRIPTION	DESIGN BY	DESIGN CHECK
REVISIONS / ISSUE				
KGS GROUP CONSULTING ENGINEERS		 THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT		
NEWPCC RAS PIPE ASSESSMENT PILOT INSPECTION PROGRAM				
SAMPLE 7 - EXISTING PIPING ISOMETRIC				
16-0107-023		ISO-002	REV: A	