



NOTES: ALL AREAS HAVE ASBESTOS CONTAINING PLASTER ABOVE DROPPED CEILING UNLESS NOTED ON SURVEY;  
 ALL EXTERIOR WALLS AND COLUMNS HAVE ASBESTOS CONTAINING PLASTER;  
 BLACK MASTIC NOTED ABOVE VARIOUS CEILING THROUGHOUT;  
**2ND FLOOR WEST**  
 SCALENTIS

**LEGEND**

GENERAL LABELS	ON CEILING	ABOVE CEILING	UNDER FLOORING	WALL DETAIL	ENCAPSULATED ASBESTOS
?? =	??	??	??	??	??

AF: ASBESTOS FABRIC	FL: FLOOR LEVELING CMP	SI: STIPPLE CEILING
BR: BOILER REFRACTORY	F9: 9X9 FLOOR TILE	SO: SPRAY ON
CA: CAULKING	F12:12X12 FLOOR TILE	ST: STUCCO
C12: 12X12 CEILING TILE	HB: HARDBOARD	TI: TANK INSULATION
C24: 24X24 CEILING TILE	MA: MASTIC	TP: TRANSITE PIPE
C48: 24X48 CEILING TILE	PF: PIPE FITTING INSULATION	VE: VERMICULITE
DC: DRYWALL COMPOUND	PI: PIPE INSULATION	
DI: DUCT INSULATION	PL: PLASTER	
FS: SHEET FLOORING	RD: ROOF DRAIN	

**NOTES:**  
 1. THERE MAY BE ASBESTOS CONTAINING MATERIALS PRESENT THAT WERE NOT LOCATED DURING BUILDING INSPECTIONS  
 2. REFER TO THE ASBESTOS INVENTORY SURVEY SHEET FOR MORE INFORMATION  
 3. DO NOT DISTURB ASBESTOS. FOR HANDLING PROCEDURES CALL CENTRAL CONTROL AT 986-2382

**ASBESTOS LOCATIONS**

BUILDING:	LO-11
REVISED BY:	REM
DATE:	JUNE 11, 2018
SCALE:	N.T.S.
SHEET #:	1/2

**CITY OF WINNIPEG**  
 PLANNING, PROPERTY & DEVELOPMENT DEPARTMENT  
 MUNICIPAL ACCOMMODATIONS DIVISION  
 4th FLOOR - 185 KING STREET  
 WINNIPEG, MANITOBA R3B 1J1  
 PHONE: (204) 986-7266  
 FAX: (204) 986-7311

*Enhance the Spirit • Value / Support*