


B SIZE - 279mm x 432mm

General DWG\1-0179F-A0007-001.dwg

LAST SAVE: 2018/12/13 - 4:52pm
 PATH: M:\657381\4ENG\48IC\DD -

TRANSFORMER XFMR-F70 SECONDARY COMPARTMENT
 (OUTDOOR SERVICE PAD)

RTU PANEL
 (ELECTRICAL ROOM)



- NOTES:**
- TEMPERATURE SETPOINT AS PER MANUFACTURER'S RECOMMENDATIONS.
 - TEMPERATURE SWITCH CONTACT TO BE OPEN WHEN TEMPERATURE IS NORMAL AND CLOSED WHEN TEMPERATURE IS ABOVE SETPOINT.



SNC-LAVALIN INC.
 148 Nature Park Way
 Winnipeg, MB, Canada R3P 0X7
 204-786-8080



THE CITY OF WINNIPEG
 WATER AND WASTE DEPARTMENT

ROLAND FLOOD PUMPING STATION
 2019 UPGRADES
 LOOP DIAGRAM
 TRANSFORMER XFMR-F70 HIGH TEMPERATURE
 TSH-F702

NO.	REVISIONS	DATE	DESIGN	CHECK
00	ISSUED FOR TENDER AND CONSTRUCTION	2018/12/14	KS	BC

DESIGNED BY: K. SAPIAK
 CHECKED BY: B. CLEVEN
 DRAWN BY: K. SAPIAK
 APPROVED BY: B. CLEVEN
 SCALE: NTS
 DATE: 2018/08/23
 ISSUED FOR CONSTRUCTION BY: K. ZUREK
 DATE: 2018/12/14
 CONSULTANT NO.:

CITY DRAWING NUMBER	SHEET	REV.	SIZE
1-0179F-A0007	001	00	B